

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/WZ/2022/ 120

Dated: 03/02/2022

**FIRE SAFETY CERTIFICATE**


Certified that **Rajender Lakra Model School** located at **Mundka, New Delhi-110041**, comprised of ground and first floor only, was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2018/WZ/735 dated 19.04.2018. The school building was re-inspected by the officer concerned of this department on 27.01.2022, in the presence of Sh. Ramchander Singh (H.o.S) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular no. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01.03.2011 and that the building/premises is fit for occupancy class "Educational" with effect from \_\_\_\_\_ for a period of three years, subject to compliance of the conditions, printed overleaf.

Issued on 03/02/2022 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Head of School,  
Rajender Lakra Model School,  
Mundka, New Delhi- 110041.
2. The Directorate of Education,  
GNCT of Delhi, Old Secretariat, Delhi- 110054.

  
02/02/22.

### Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

2/11

**INSPECTION REPORT**

1. Name & address of the building : Rajender Lakra Model School located at Mundka, New Delhi- 110041.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/ WZ/735 dated 19/04/2018
5. Fire Safety directives letter No : D.o.E cir. F6/Estate/CC/Fire/Safety/2011/3298-3398 dt. 01.03.2011
6. Date of inspection : 27.01.2022
7. Name of the Inspecting Officers : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of officers  
from the building side : Sh. Ramchander Singh, Head of School
9. Year of Construction : 1982
10. Applicant's letter No. : nil dt. 09.12.2021

Rajender Lakra Model School is comprised of ground and first floor each.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	01	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.50 mts each	1.20, 0.80 mts	MR being old case
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.0 mt	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

*Handwritten signature*

4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	06 nos.	Provided	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	<b>MOEFA</b>			
		N/A	N/A	N/A
9	<b>Public Address System.</b>			
		N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	<b>Pumping Arrangements</b>			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A

N/13

14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts. Not Applicable</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required 02 ABC type fire extinguishers near elect. panel	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2018/ WZ/735 dated 19/04/2018, renewal under D.o.E cir. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01.03.2011, is recommended.

DFA is put up for approval & signature please.

*Q.111 to 111*  
*27/01/22.*

Signature of the Inspecting Officer  
(Aman Kumar Lathar)  
Asst. Divisional Officer (JWP)

~~D.O. (West Division)~~

*dy*  
*22/01/2022*

*Defo (W2)*

*24/1/2022*

D.O. (WEST)/235  
DATED..27/1/2022

*ADJ JWP*

P.T.O.