

E-28

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No: F6/DFS/MS/MN/2021/EH/20

Dated: 27/01/2022

FIRE SAFETY CERTIFICATE

Certified that the **Backyard Restaurant (A unit of Slurp Hospitality)** located at **49, GF, North West Avenue, Punjabi Bagh Extension, New Delhi - 110026** in a building comprised of Ground + three upper floors, was issued FSC Vide Letter No. F.6/DFS/MS/2018/WZ/EH/1157 dated 21/05/2018. The premises was re - inspected by the officer concerned of this department on 13/12/2021 in the presence of Sh. Rohit Kumar Jha (Manager) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said floor is fit for occupancy class "Assembly" Group-D (for Ground floor Only) with effect from 27/01/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned overleaf.

Issued on 27/01/2022 at New Delhi.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

1/c JPP
27/01/2022

Copy to:-

1. The Owner/Occupier of Backyard Restaurant (A unit of Slurp Hospitality), 49, GF, North West Avenue, Punjabi Bagh Extension, New Delhi – 110026.
2. Dy. Health Officer (West Zone), South Delhi Municipal Corporation, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per building bye laws.
6. Use of terrace above third floor for restaurant purpose is not allowed. If it is used, FSC is null & void.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The Owner/ Occupier shall apply for the renewal of this Fire safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate , six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Backyard Restaurant (A unit of Slurp Hospitality), 49, GF, North West Avenue, Punjabi Bagh Extension, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/ DFS/MS/2018/EH/1157 dated 21/05/2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 13/12/2021
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO(MN)
8. Name and designation of officers from the building side : Sh. Rohit Kumar Jha (Manager)
9. Year of Construction : 2018 (As per MHA portal)
10. Applicant's letter No. : Online Application No. 2021090219852 dated 21/10/2021

Note:- The said restaurant is running at Ground floor in a building comprised of Ground Plus Three upper floors.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement(As per. prev. insp. rpt. dtd 02/05/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NR	NR	NR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NR	NR	NR
	• Basements	NR	NR	NR
	b. Width of staircases			
	• Upper Floors	NR	NR	NR
	• Basements	NR	NR	NR
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	e. No. of continuous staircases to terrace	NR	NR	NR
	g. Width of Corridor	NR	NR	NR
	h. Door Size	2m & 1 m	2m, 1m, 76m, 91 cm	MR
3	Compartmentation.			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	NR	NR	NR
	• Upper floors	NR	NR	NR

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types 	05	08 Provided	MR
		CO ₂ Water Co ₂ type		Provided
	<ul style="list-style-type: none"> IS marking 	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30 m Required	Provided	MR
5 mm		Provided	MR	
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NR	Provided	NR
		NR	GF	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
NR		NR	NR	
8	MOEFA		Required	Provided
9	Public Address System.		NR	NR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
NR		NR	NR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	Required	Provided	MR
		1	Provided	MR
1		Provided	MR	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NR	NR
		NR	NR	NR
NR		NR	NR	
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
	NR	NR	NR	
		450 lpm	Provided	MR
		30mtr	Provided	MR
	Required	Provided	MR	
	Required	Provided	MR	
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
NR		NR	NR	

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 	NR	NR	NR
15	Exit Signage.	10,000 ltrs	Provided ✓	MR
16	Provision of Lifts.	Required	provided ✓	MR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NR	NR	NR
		NR	NR	NR
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	NR	NR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued by this department vide letter no. F6/DFS/MS/2018/EH/1157 dated 21/05/2018 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Do (West)

Signature
isindry

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Asst. Divisional Officer (MN)

D.O. (WEST)/331
DATED 22/12/2021

22/12/2021

Defo (W2)

24/12/2021

DO (MN)

Sin F.T is put up for your personal & Signatures please

Dy (W2)

check part no-14

Signature

DO (West)

24/1/2022

24/1/2022

ADD (MN)