

C-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2022/ 33

Dated : 09.02.2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Carnival Restaurant and Bar located at 23-1-E-Plot No.23, Ground Floor, Jhandewalan , New Delhi comprised of Basement, Ground plus Third upper floors and Restaurant running at Ground floor only . The premises was inspected by Officers concerned of this department on 31/01/2022 in the presence of Mr. Deepak and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building Group D (restaurant at ground floor only), with effect from 09/02/2022.....for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 09/02/2022 at New Delhi by.


(Atal Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Commissioner , North MCD , Civic Centre , New Delhi
2. The Addl. Commissioner of Police(Lic) , Ist floor,PS Defence Colony , New Delhi ID NO 2021122429274 dated 24.12.2021
3. The Manager,
M/s Carnival Restaurant and Bar, 23-1-E-Plot No.23, Ground Floor, Jhandewalan,
New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for Ground Floor Restaurant only.**
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is strictly prohibited.

111

INSPECTION REPORT

1. Name & address of the building Carnival Restaurant and Bar located at 23-1-E-Plot No.23, Ground Floor, Jhandewalan New Delhi **comprised of Basement, Ground plus Third Upper floors and Restaurant running at Ground floor only**
2. Type of occupancy:- Assembly Building Group-D
Restaurant running at ground floor only
3. Type of case:- New Cases
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 31/01/22
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) &
Sh. Ravinder Singh (ADO/CD)
8. Name & designation of officer
From the building side:- Sh. Deepak
9. Year of construction:-
10. Applicant's letter No:- Online id. 2021122429274 dated 24.12.2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements as per UBBL-2016 & NBC part-4	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2x1.5 mtr	2x1.5 mtr	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	04 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

Handwritten signature

M/2

6.	First-Aid Hose Reel			
	1) Total number at ground floor	01	Provided	MR
	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR



16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Further, first floor is used as office and second & third floor is found vacant.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, the Fire Safety Certificate under rule 35 of Delhi Fire Service Rules-2010 is recommended for approval.

Signature of the Inspecting Officer

Rajinder Atwal
31/2/22

Name:- Rajinder Atwal
Designation:-DO(CD)

Signature of the Inspecting Officer

Ravinder Singh
31/2/22

Name:- Ravinder Singh
Designation:- ADO (CC)

Dy. Chief
7/2/22

ADOMR
7/2/22

CFO (CD) - D/02

Director
8/02/2022

ADCD

8/2

AD (CC)

As approved, AD (CC) dated for issue permit and separate please.

Director
9/02/2022

AD (CC)
9/2/22

