

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2022/ 138

Dated: 10/2/2022

FIRE SAFETY CERTIFICATE

Certified that the New Building Block, Govt. Co-Ed. Sarvodaya Vidhlaya School, Located at Kailash Enclave, Saraswati Vihar, Delhi-110034 comprised of Ground + 03 Upper Floors owned/ occupied by Govt. Co-Ed. Sarvodaya Vidhlaya School, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on 04.02.2022 in the presence of Ms. Neera Nashier (H.O.S) & Sh. Santosh Rai (Representative) and that the building/premises is fit for occupancy class " Educational Building" Group B with effect from 10/2/22 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/2/22 at New Delhi by.


(Anil Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054
2. The Assistant Engineer (E), PWD Sub Division 2, Edu. Elect. Edn. 1 Div (N), Sector 16, Rohini, Delhi-110089.
3. The Principal, Govt. Co-Ed. Sarvodaya Vidhlaya School, Located at Kailash Enclave, Saraswati Vihar, Delhi-110034.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

11/24
INSPECTION REPORT

1. Name & address of the building: **Govt. Co-ed. Sarvodaya Vidyalaya School** Located at **Kailash Enclave, Saraswati Vihar, Delhi-110034.**
2. Type of Occupancy : Educational
3. Type of Case : **New Building Block (G + 03 Upper Floors)**
4. Details of previous NOC : F6/DFS/MS/School/WZ/2021/622 dated 19.08.2021 (For Old Building)
5. Fire Safety directives Letter No. : as per UBBL/NBC Part-IV
6. Date of inspection : 04.02.2022
7. Name of the Inspecting Officer : S.P. Bhardwaj, Divisional Officer
8. Name and designation of Officer from the building side : Ms. Neera Nashier (H.O.S)
Sh. Santosh Rai (Representative)
9. Year of Construction : 2021-22
10. Applicant's letter No. : email dated 01.02.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs.	Provided	MR
	• Gate width	4.5 mtrs.	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04 & 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtrs.	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04	Provided	MR
	e. Width Of Corridor	1.5 mtrs.	Provided	MR
	f. Door Size	1.2 mtrs.	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	36 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	05	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

Sy

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided (2 nos.)	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr	20,000 Ltrs.	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	Not yet installed		
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO ₂ type fire ext. near electrical panels	MR

[Handwritten signature]

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

[Signature]
S.P. Bhardwaj 5/21/22
Divisional Officer

~~Do/wsl. JPH~~
~~Defect wz~~

[Signature]
8/27/2022

CFD



Kemp
92

~~Sd/- M/ 9/02/22~~

FT P 5

Do/wsl

FT is put up for signature

~~*[Signature]*~~
~~10/02/2022~~

[Signature]
9/14/22

MAM