

C-11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2022 / School / WZ / 115

Dated 03/02/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Sarvodaya Kanya Vidyalaya (New Block)** located at **Alipur, Delhi-110036** comprised of **Ground+Three upper floors** owned/ occupied by **Govt. Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of Fire Service on **17.01.2022** in the presence of **Sh. Sanjay Chauhan** and found that the building is fit for **occupancy class Group B Educational** with effect from - **03/02/2022** for a period of **03 (Three) years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **03/02/2022** at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  


Copy to:-

1. The Director , Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. Principal , Govt. Sarvodaya Kanya Vidyalaya, Alipur , Delhi-110036.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

2/2

### INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya (New Building) located at Alipur, Delhi-110036
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Three Upper Floors (03 Blocks interconnected)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 17/01/2022
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers From the building side : Sh. Sanjay Chauhan
10. Year of Construction : 2021
11. Applicant's letter No. : E Mail ID, Dated-13/01/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b> <ul style="list-style-type: none"><li>Road width</li><li>Gate width</li><li>Width of internal road</li></ul>	6.0 m 4.5 m NA	6.0 m 4.5 m NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b> <p>a. Number of staircases</p> <ul style="list-style-type: none"><li>Upper Floors</li><li>Basements</li></ul> <p>b. Width of staircases</p> <ul style="list-style-type: none"><li>Upper Floor</li><li>Basements</li></ul> <p>c. Protection of exits</p> <ul style="list-style-type: none"><li>Fire check door</li><li>Pressurization</li></ul> <p>d. No. of continuous staircases to terrace</p> <p>e. Width of Corridor</p> <p>f. Door Size</p>	04 NA 1.50 m each NA NA NA NA NA 02 1.50 m 1.20 m	04 NA 1.70 m each NA NA NA NA NA 04 1.70 m 1.20 m (Double Door)	MR NA MR NA NA NA NA NA MR MR
3.	<b>Compartmentation</b> <ul style="list-style-type: none"><li>Fire check door</li><li>Sealing of electrical shafts</li><li>Fire Rating of shaft door</li><li>Water Curtain</li><li>Fire Dampers</li></ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	<b>Smoke Management System</b> <ul style="list-style-type: none"><li>Basements</li></ul>	30 a/c per hour	NA	NA

a

	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	25	46	MR
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC/CO2	ABC/Co2	MR
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Yes	Yes	MR
<b>6.</b>	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	03 Nos.	03 Nos.	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	Provided	MR
<b>7.</b>	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
<b>8.</b>	<b>MOEFA</b>	NA	NA	NA
<b>9.</b>	<b>Public Address System</b>	NA	NA	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping</li> </ul>	NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> </ul> </li> <li>➤ Auto Starting of pump</li> </ul>	450 lpm	450 lpm×2	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	10,000 ltrs	MR
		Required	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>			
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>17.</b>	<b>Standby power supply</b>	NA	NA	NA
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Battery backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures required under rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

ADG/ADW on plot

Dyefo (WZ)

*[Signature]*  
27/1/2022

CAF

deame  
27/1/22

Dia / ADW/gov  
27/1/2022

ADG/ADW F.T letter in prop for sign pleas

Director (AS)  
27/1/2022


*[Signature]*

*[Signature]*  
ADO (B.W.)  
13/1/22

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.



*[Signature]*  
ADO (B.W.)  
28/1/22