

DFA

c6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2022/ 139

Dated: 10/2/2022

FIRE SAFETY CERTIFICATE

Certified that the **New Block, Govt. Girls Sr. Sec. School (ID-1411046)**, Located at **Kohat Enclave, Anandvas, Pitampura, Delhi-110034** comprised of **Ground + 03 Upper Floors & MP Hall** owned/ occupied by **Govt. Girls Sr. Sec. School (ID-1411046)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on 04.02.2022 in the presence of Ms. Nisha Tyagi (Vice-Principal) & Sh. Deepak Tyagi Site Engineer (SPG Infra Pvt. Ltd.) and that the building/premises is fit for occupancy class "Educational Building" Group B with effect from 10/2/22 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/2/22 at New Delhi by.


Atul Garg
Director
Su

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054
2. The Assistant Engineer (E), PWD Sub Division 2, Edu. Elect. Edn. 1 Div (N), Sector 16, Rohini, Delhi-110089.
3. The Principal, New, Govt. Girls Sr. Sec. School, Kohat Enclave, Anandvas, Pitampura (ID-1411046), Delhi-110034.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

21-1

INSPECTION REPORT

1. Name & address of the building: **Govt. Girls Sr. Sec. School (ID-1411046)**
Located at **Kohat Enclave, Anandvas, Pitampura, Delhi-110034**
2. Type of Occupancy : Educational.
3. Type of Case : **New Block=G+03 Upper Floor & M.P. Hall**
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : as per UBBL/NBC Part-IV
6. Date of inspection : 04.02.2022
7. Name of the Inspecting Officer : S.P. Bhardwaj, Divisional Officer
8. Name and designation of Officer
from the building side : Ms. Nisha Tyagi (H.O.S)
Sh. Deepak Tyagi, Site engineer (SPG infra pvt. Ltd.)
9. Year of Construction : 2021-22
10. Applicant's letter No. : email dated 01.02.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs.	Provided	MR
	• Gate width	4.5 mtrs.	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04	04 & 01 ramp	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtrs.	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04	Provided	MR
	e. Width Of Corridor	1.5 mtrs.	Provided	MR
	f. Door Size	1.2 mtrs.	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	38 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	04	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floo Hose Box 	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm	Provided (2 nos.)	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000Ltrs.	20,000 Ltrs.	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO ₂ type fire ext. for electrical panel	MR

Signature

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Note: - Management has constructed a separate M. P. Hall having seating capacity of 300 persons (18x30 m) & have provided 04 nos. exit doors (03 Nos. 1.5m wide & 01 No. 2 m wide) & protected with hose reels & hydrant.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

Suy
8/21/22
S.P. Bhardwaj
Divisional Officer

~~Do/wat/Do#~~
~~Defo/wz~~

~~8/21/22~~



CFO

~~9/2~~

~~9/2/22~~

~~Do/wat~~

FT is put up for signat per

~~Director~~
~~10/02/2022~~

Suy
8/21/2022

mu