

C-51

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No. F.6/DFS/MS/School/2022/SZ/ 104

Dated: 02/02/2022

FIRE SAFETY CERTIFICATE

Certified that **St. Mary's Public School** located at **530, Durga Vihar, Devli, New Delhi-110062** comprised of ground plus two upper floors only was issued FSC by this department vide letter No. F6/DFS/MS/School/2018/SZ/2714 dated 14/12/2018. The said premise was re-inspected by officer concerned of this department on 27/01/2022 in the presence of Dr. Thomas George (Director) and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "**Educational Building**" **Group-B, (School)** with effect from 02/02/2022 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 02/02 /2022 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, St. Mary's Public School, 530, Durga Vihar, Devli, New Delhi-110062
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	St. Mary's Public School located at 530, Durgam Vihar, Delhi, New Delhi-110062					
2	Type of Occupancy	Educational, Group B (School)					
3	Building Comprised of	Ground + 02 upper floors.					
4	Type of Case	Renewal					
5	Details of Previous NOC	F6/D/FS/MS/School/2018/SZ/2714 dated 14/12/2018					
6	Fire Safety Directives Letter No	Nil					
7	Date of Inspection	27-01-2022					
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)					
9	Name & Designation of Officers from the building side	Dr. Thomas George (Director)					
10	Year of construction	2005					
11	Applicant letter No.	Gmail dated 25-01-2022					
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old Noc requirements	Provided at Site	Remarks MR/N/MR			
1.	Access to Building.	• Road width	6 mtr	5.70 m	MR (old case)		
		• Gate width	3.5 mtr	3.5 mtr	MR		
		• Width of internal road	-NA-	-NA-	-NA-		
2	Number, width, type & arrangement of exits.	a) Number of Staircase	➤ Upper floors.	02 Nos	02 Nos	MR	
			➤ Basement floor.	-NA-	-NA-	-NA-	
		b) Width of Staircase	➤ Upper floors	1.5 m	1.90m & 0.85 m	MR (old case)	
			➤ Basement floor	-NA-	-NA-	-NA-	
		c) Protection of exits	➤ Fire check door	-NA-	-NA-	-NA-	
			➤ Pressurization	-NA-	-NA-	-NA-	
		d) No. of continuous staircase to terrace	One	Provided	MR		
		e) Width of corridor	1.50 m	Provided	MR		
		f) Door size	1m	Provided	MR		
			3	Compartmentation.			
		4.	Smoke Management system.	• Fire check door.	-NA-	-NA-	-NA-
				• Sealing of electrical shafts.	-NA-	-NA-	-NA-
• Fire rating of shaft door.	-NA-			-NA-	-NA-		
• Water curtain	-NA-			-NA-	-NA-		
• Fire dampers.	-NA-			-NA-	-NA-		
• Basement	30 ACPH			-NA-	-NA-		
5.	Fire Extinguishers.	• Upper floors	12 ACPH	-NA-	-NA-		
		• Total numbers	15 Nos	15 Nos	MR		
6.	First Aid Hose Reels.	• Types	ABC / CO2	CO2 & ABC	MR		
		• ISI Marking	ISI marked	Provided	MR		
	• Total numbers on each floor.	One at each	Provided	MR			

	<ul style="list-style-type: none"> Length of hose-reel hose. 	30m	Provided	MR
	<ul style="list-style-type: none"> Nozzle Diameter 	5mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Alternate source of power 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	NA	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Head of main pump. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Pump house access. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of pump. 	40m	Provided	MR
	<ul style="list-style-type: none"> ➤ Power supply. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication in lift car. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's switch. 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift signage. 	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-

18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/2714 dated 14/12/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

[Handwritten Signature]
28/1/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

~~DO (SD)~~

[Handwritten Signature]
31/01/22

[Handwritten Signature]
DCFO(S)

F.T.

[Handwritten Signature]

[Handwritten Signature]
A DO (BCP)

As approved, F-T letter is put up for your signature pl

[Handwritten Signature]
1/2/2022

[Handwritten Signature]
DCFO(S)

[Handwritten Signature]

M.S. cell