

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 1059

Dated: 23/12 /2021

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys. Sr. Sec. School No-4 located at Sarojini Nagar, New Delhi-110023, comprised of Ground & Two Upper Floor owned / occupied by Govt Boys. Sr. Sec. School, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/SZ/143 dated 18/01/2019. The premises was re-inspected by the officer concerned of Fire Service on 14/12/2021 in the presence of Sh. Hitender Yadav (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational" (Group-B) with effect from 23 / 12 / 2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 23/12/21 at New Delhi by



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.)



Copy to :-

1. The Manager, Govt. Boys. Sr. Sec. School No-4, Sarojini Nagar, New Delhi-110023.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

21-8
INSPECTION REPORT

1. Name & address of the building: Govt. Boys. Sr. Sec. School No-4, Sarojini Nagar, New Delhi-110023.
2. Type of Occupancy : Educational, Group-B (School)
3. Building Comprised of : Ground & Two Upper Floors only
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2019/SZ/143 dated 18/01/2019
6. Fire Safety directives Letter No. : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01.03.11
7. Date of inspection : 14/12/2021
8. Name of the Inspecting Officer : A.D.O. (S.J.)
9. Name and designation of Officer from the building side : Sh. Hatinder Yadav (Principal)
10. Year of Construction : 1962
11. Applicant's received email: ID-gbsssno4sarojininagar@gmail.com dated 01/12/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per COE Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	7m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 Nos	02 Nos	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m / 0.75m	1.60m (Each)	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	Provided 02 Nos	MR
	c. Width Of Corridor	1.5m	Provided	MR
	d. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	20 Nos	22 Nos	MR
	• Types	ABC /WC02	ABC & Co2	MR
	• ISI marking	ISI Marked	ISI Marked	MR

6. First - Aid Hose Reels				
	• Total numbers on each floor	2	Provided at each floor	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7. Automatic fire detection and alarming system				
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA

8.	MOEFA	NA	NA	NA
----	-------	----	----	----

9.	Public Address System	NA	NA	NA
----	-----------------------	----	----	----

10. Automatic Sprinkler System				
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11. Internal Hydrants				
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA

12. Yard Hydrants				
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

13. Pumping Arrangements				
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450LPM	450LPM X 2	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR


14. Captive water Storage for fire fighting				
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 Liters	Provided	MR

N/10

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2019/SZ/143 dated 18/01/2019 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : A.D.O. (S.J.)

~~DO/SJ~~


~~Riv~~
14/1/21 F.T.

~~DO/SZ~~



A.O.O. (S.J.)

F.T. is added please.

DO/SZ 


 22/1/21 2021

M-5. 10/11