

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / Indl./2022/WZ/ 57

Dated: 08/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Agarwal Pharmaceuticals, located at B-2644, DSIDC Industrial Complex Narela, Delhi-110040 comprised of Basement, Ground & Two Upper Floors owned/occupied by M/s Agarwal Pharmaceuticals was issued No Objection Certificate vide Letter No. F5/(5)/DFS/2003/681 dated 06/11/2003 and re-inspected by the officers concerned of this department in presence of Mrs. Neeta Dey on 02/02/2022 and found that building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 36 and sub Rule 6 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy under Class "Industrial Building G-2(ii)" with effect from 08/02/2022..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 08/02/2022 at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy to :-

1. M/s Agarwal Pharmaceuticals, B-2644 Narela Industrial Complex, Delhi-40.

Distt. Excise Officer(M&TP), Govt. of NCT of Delhi, L & N block, Vikas Bhawan, New Delhi

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Agarwal Pharmaceuticals located at B-2644, DSIDC Industrial Complex, Narela, Delhi-110040.
2. Type of Occupancy : Industrial G-2(ii)
3. Building Composition : Small Basement(Storage), Ground(office & working hall),First Floor(Packing Purpose & one small lab),Second floor(Packing purpose)
4. Type of Case : Renewal
5. Details of Previous NOC : F.5/(5)/DFS/2003/681 Dated- 06/11/2003
6. Fire Safety directives letter No : Nil
7. Date of inspection : 02/02/2022
8. Name of Inspecting Officer : DO (NW) & ADO(BW)
9. Name and designation of officers from the building side : Smt. Neeta Dey (Administrative officer)
11. Year of Construction : 2001
12. Applicant's letter No. : E Mail id Dated 25/01/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Old NOC at C-38 & Rule-36(6)	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	6m	No boundary wall, directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floor	1.10 m	1.10 m	MR(Old Case)
	• Basements	1.30 m & 1 m	1.30 m & 1 m	MR(Old Case)
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01	Provided	MR
		NA	NA	NA
		NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	12 ac/hr	Exhaust fan provided	MR
	• Upper floors	12 ac/hr	Natural Ventilation	MR

5.	Fire Extinguishers	Required	16 nos	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ABC/CO2/Mechanical	Provided	MR
		Foam	Provided	MR
		Required	Provided	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	Provided	MR
		30 m	Provided	MR
		05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		4000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR

Pr

Provision of Lifts.		One Goods lift only.		
<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18. Refuge Area.				
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19. Fire Control Room				
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Shortcomings issued vide letter no. F 6/DFS/MS/Indl./WZ/2021/634 dated 17.02.2021 has been removed by the owner/occupier.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rule 36(6) it is recommended to renew No Objection Certificate issued vide letter no. F.5/(5)/DFS/2003/681 dated 06/11/2003 under rule 35 of Delhi Fire Service Rules 2010.

[Signature]
04/02/2022

Signature of Inspecting Officer
Name:- D.B Mukharjee
Designation:- DO(NW)

[Signature]
ADO (BW)
3/2/22

Signature of Inspecting Officer
Name: Rajeev Kumar Sinha
Designation; ADO(BW)

[Signature]
Dy CTO (WZ)

[Signature]
8/2/2022

[Signature] ADO/BW F.T letter of Duten for sign please

[Signature]
Dy CTO (WZ)

[Signature]
8/2/2022

[Signature]
ADO (BW)
8/2/22

[Signature]
net all