

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Assembly/SZ/2022/ 59

Dated: 09/09/2022

FIRE SAFETY CERTIFICATE

Certified that **Auditorium Building** Situated at **Inter University Accelerator Centre, Aruna Asaf Ali Marg, New Delhi 110067** comprised of **Ground and First Floor** was issued FSC by this department vide letter no. F6/DFS/MS/Assembly/SZ/2019/210 dated 28/01/2019. The premise was re-inspected by the officer concerned of this department on 02.02.2022 in the presence of Mr. Harshwardhan Singh and found deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Group "D" Assembly Building (Auditorium 263 Seats)**" with effect 09/02/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 09/02/2022 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. Sh. Bishwambhar Datt (Senor Administrative Officer) Auditorium Building at Inter University Accelerator Centre, Aruna Asaf Ali Marg, New Delhi 110067.
2. The Executive Engg. (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024.

Conditions for the validity of fire safety certificate:

1. The owner/occupier shall occupy the auditorium only after issue of license by the Dy. Commissioner of concerned revenue District of NCT of Delhi as notified by revenue department, Govt. of NCT of Delhi vide Delhi Gazette notification dated 09/01/2015.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

20/11/22

INSPECTION REPORT

1. Name & address of the building : Auditorium Building at Inter University Accelerator Center Aruna Asif Ali Marg, New Delhi- 110070.
2. Type of Occupancy : **Group "D" Assembly Building [Auditorium 263 Seats]**
3. Type of Case : Renewal
4. Comprised of : **Ground & First Floor**
5. Details of Previous NOC : F6/DFS/MS/Assembly/SZ/2019/210 dated 28/01/2019
6. Fire Safety directives letter No : F6/DFS/MS/BP/2000/2112 dated 17/11/2000
7. Date of inspection : 02/02/2022
8. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
9. Name and designation of officers from the building side : Mr. Harshwardhan Singh
10. Year of Construction : 2018
11. Applicant's letter No. : IUAC/Admn./14/1192 dated 13/01/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 5m 6m	Provided Provided Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 Nos -NA-	03 Provided -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m -NA-	1.6m, 1.6m & 0.94 m -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	Required	2 Nos	MR
	Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.5m	1.9m, 1.92m, 1.7m & 1.68 m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required Required -NA- Required	Provided Provided Provided -NA- Provided	MR MR MR -NA- MR
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	-NA- 12 ACPH	-NA- Provided	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 No's ABC/W.CO ₂ /CO ₂ Required	Provided 4/4/2 Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	Smoke & Heat Required -NA-	Provided Ground Floor -NA-	MR MR -NA-

	<ul style="list-style-type: none"> • Alternate source of power • Hooters' Location 	Required Required	Provided All Floors	MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Ground & Above Floors • Sprinkler above false ceiling 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm 2 Nos 2 Nos	Provided GF-4 No & FF-2 No GF-4 No & FF-2 No	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	-NA- -NA-	02 Nos Provided 02 Nos Provided	-NA- -NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-
	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	450 LPM 40m Required Required	2 x 900 LPM Provided Provided Provided	MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-NA- -NA- Required Required 10,000 Lts. Required	-NA- -NA- Provided Provided Provided Provided	-NA- -NA- MR MR MR MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-NA- -NA- -NA- -NA- -NA- Required	-NA- -NA- -NA- -NA- -NA- Provided	-NA- -NA- -NA- -NA- -NA- MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-

N/16

20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-
-----	---	------	------	------

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Assembly/SZ/2019/210 dated 28/01/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Sh. Rajesh Kumar
4/2/2020

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

Sh. Rajesh Kumar

DO (SD)

[Signature]

ADO (BCP)

As approved, F.T. letter is put up for your signature pl

Sh. Rajesh Kumar
8/2/2020

DO (SD)

[Signature]

M.S. [Signature]