

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2022/ *(Pete) 64*

Dated:- *11/02/2022*

**FIRE SAFETY CERTIFICATE**

Certified that the **BPCL Modern Service Station** located at **Janpath, Connaught Place, New Delhi** comprised of **Ground floor & 1<sup>st</sup> floor** owned/occupied by BPCL Modern Service Station was earlier granted FSC by this department vide letter No. **F6/DFS/MS/NDZ/2018/2748** dated **27/12/2018**. Now, the premises was re-inspected by the officer concerned of this department on **08/02/22** in the presence of Sh. Dinesh Kumar (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous Group J** with effect from *11/02/2022* for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued *11/02/2022* at New Delhi by.

*(Dr. S.K. Tomar)*  
*11/2/22*

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

*R*

Copy to:-

1. The Manager,  
BPCL Modern Service Station,  
Janpath, Connaught Place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
3. 04 nos of CO2 gas type ISI capacity of 4.5 kg, 02 nos of ABC stored pressure power type ISI capacity 05 kg and 01 number of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
4. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building BPCL Modern Service Station at 35 Janpath, Connaught Place, New Delhi
2. Type of occupancy:- Hazardous Group J  
Ground floor & 1<sup>st</sup> floor
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6)/DFS/MS/NDZ/2018/2748 dated 27/12/18
5. Fire safety directives No.- N/A
6. Date of inspection:- 08/02/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Sh. Dinesh Kumar (Manager)
9. Year of construction:-
10. Applicant's letter No:- Nil dated 28.12.21.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	Accessible	Accessible directly	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
	<b>A. Number of staircases</b>			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.2 mtr.	1.2 mtr.	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
<b>5. Fire Extinguishers</b>				
	1) Total numbers	07	08	MR
	2) Types ABC , Foam , Co2	Required	Provided	MR
	3) ISI marking	Required	Provided	MR
<b>6. First-Aid Hose Reel</b>				
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A

<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
<b>15.</b>	<b>No Smoking Signage English &amp; Hindi</b>	Required	Provided in English & Hindi	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A




	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckets with sand.</b>			MR


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide lette no. F6/DFS/MS/NDZ/2018/2748 dated 27/12/2018 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

  
 Name: - Ravinder Singh  
 Designation: - ADO (CC)

~~DO/CD~~

  
 10/2/22

Dy. CPO (MS)

  
 10/2/22

ADO (CC)

As approved, Pm put up for new Renewal and Reposition Plan

  
 11/2/22

Dy. CPO (MS)

  
 11/2/22

MS

