

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

948

No.F6/DFS/MS/BQ/NDZ/2022/ 09

Dated : 11 .02.2022

FIRE SAFETY CERTIFICATE

Certified that the M/s **Golden Knot (A unit of Unique Enterprises) Banquet Hall** located at **B-15, Main Road, Gazipur, Delhi** comprised of B + Gr. + Mezzanine + 01 upper floor, Banquet running at Ground & Mezzanine floor only owned/occupied by Golden Knot Banquet Hall was granted FSC by this department vide letter No. F6/DFS/MS/BQ/2018/NDZ/378 dated 08/03/18. The premises was re-inspected by the officers concerned of this department on 31/01/2022 in the presence of Mr. Aamir Khan and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy "**Assembly Building**" Class "**D**" (**Banquet Hall**), **Banquet running at Ground & Mezzanine floor only** with effect from 11/02/2022 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 11/02/2022 at New Delhi by.

(S.K. Tomar)
9/2/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

(Signature)

Copy to:-

1. The Deputy Commissioner (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi. **online application ID. 2021113027521.**
2. The Manager,
M/s Golden Knot (A unit of Unique Enterprises) Banquet Hall,
B-15, Main Road, Gazipur, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

- 2/14 -
INSPECTION REPORT

1. Name & address of the building M/s Golden Knot (A unit of Unique Enterprises) Banquet Hall located at B-15, Main Road, Gazipur, Delhi.
2. Type of occupancy:- Assembly Building (Community Hall) Basement, Ground, Mezzanine + 01 Upper floor. (Banquet Hall running at Gr. & Mezz. floor only)
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/BQ/2018/NDZ/378 dated 08/03/18
5. Fire safety directives No.- NBC Part IV
6. Date of inspection:- 31/01/2022
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer From the building side:- Mr Aamir Khan
9. Year of construction:- 2000
10. Applicant's letter No:- ID No.- **2021113027521** dated 24/12/2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC Part-IV/ BBL	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	15 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 no.	02 nos.	MR
	2. Basements	02 nos.	02 nos. + Ramp	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.5 mtr. & 0.90 mtr.	MR
	2. Basements	1.5 mtr.	1.5 mtr. & 0.90 mtr. + ramp	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 no.	02 nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.	04 mtr. & 1.5 mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Ventilated	MR
	2) Upper floors	Required	Ventilated	MR

5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	MR
	2) Location of main panel	Main gate	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	Staircase	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1. Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2. Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A

3

MR
MR
MR

2/16 -

	a) Draw-off connection	N/A	N/A	
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltr.	25,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/BQ/2018/NDZ/378 dated 08/03/18 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Mursh

Name :- M.K. Sharma *31/02/22*

Designation :- ADO (LN)

~~Dy.CFO/NDZ~~

Q. Sharma
7/2/22

~~ADO (LN)~~

F.T. letter is put up for sig. of

~~Dy.CFO (NDZ)~~

Q. Sharma
9/2/22

Mursh
09/2

MS

