

G13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ | 159

Dated: 11/02/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of Govt. Boys Sr. Sec. School, Ghumanhera, New Delhi-110073, is comprised of ground plus one upper floor, was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2016/SZ/246 dated 11/02/2016. The School building was re-inspected by the officer concerned of this department on 29/01/2022 in the presence of Sh. Dilbagh Singh (Estate Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 11/02/2022 ..... at New Delhi.



(SUNIL CHAWDHARY)  
DY.CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Dep

Copy to:-

1. The Principal,  
Govt. Boys Sr. Sec. School,  
Ghumanhera, New Delhi-110073
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Govt. Boys Sr. Sec. School, Ghumanhera, New Delhi-110073.  
 2. Building is comprised of : Ground plus one upper floor.  
 3. Type of Occupancy : Educational  
 4. Type of Case : Renewal  
 5. Details of Previous NOC : F.6/DFS/MS/school/2016/SZ/246 Dt. - 11/02/2016.  
 6. Fire Safety direction letter No : N/A  
 7. Date of Inspection : 29/01/2022  
 8. Name of the Inspecting Officers: : ADO R.K. YADAV  
 9. Name of the designation of Officer from the building side : Mr. Dilbagh Singh (Estate Manager)  
 10. Year of Construction : 1967-68  
 11. Applicant's letter No : Ref. no. 428 Dated -24/01/2022

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR	
1	<b>Access to building</b>				
	Road width	Accessible	6 m	MR	
	Gate width		4.8 m	MR	
	Width of internal road	N.A.	N.A.	N.A.	
2	<b>Number, Width, Type and Arrangement of Exits</b>				
	a. Number of Staircases	Upper Floor	01 no.	01 no.	MR
		Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	Upper Floor	N.A.	N.A.	N.A.
		Basement	1.50 m	1.60 m	MR
	c. Protection of exits	Fire check door	N.A.	N.A.	N.A.
		Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	One	N.A.	
	g. Width of Corridor	1.5 m	2.37 m	MR	
	h. Door Size	1 m	.97 & 1.0 m (Double Door)	MR,old case	
	3	<b>Compartmentation.</b>			
Fire check door		N.A.	N.A.	N.A.	
Sealing of electrical shafts		N.A.	N.A.	N.A.	
Fire rating of shaft door		N.A.	N.A.	N.A.	
Water curtain		N.A.	N.A.	N.A.	
Fire Dampers		N.A.	N.A.	N.A.	
4	<b>Smoke Management System.</b>				
	Basement	N.A.	N.A.	N.A.	
	Upper floor	Required	Natural Ventilation	MR	

N/18

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	10 Nos.	10 Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
<b>8</b>	<b>MOEFA</b>	N.A.	N.A.	N.A.
<b>9</b>	<b>Public address System.</b>	N.A.	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

W

15/11

14	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	<b>Exit Signage.</b>	N.A.	N.A.	N.A.
16	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	<b>Standby power supply</b>	N.A.	N.A.	N.A.
18	<b>Refuge Area.</b>			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	<b>Fire Control Room</b>			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N.A.	N.A.	N.A.

. The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter number F.6/D/S/MS/School/2016/SZ/246 dated 11/02/2016 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

*R. K. YADAV*  
27/02/2022

Signature of the Inspecting Officer  
Name R. K. YADAV  
Designation ADO (JKP)

D.O (SOUTH WEST)

*[Signature]*  
8/2/2022

*[Signature]*  
Dy S/O (SZ)

*[Signature]*  
A. P. J. A.