

C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI**


No. F6/DFS/MS/School/WZ/2022 | 146

Dated: 10/02/2022

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Vidyalaya Jai Dev Park (ID-1515001)(New Building) located at Jai Dev Park, Punjabi Bagh New Delhi-110015, comprised of Ground Floor + 03 Upper Floors owned/Occupied by Govt. Sarvodaya Vidyalaya Jai Dev Park have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and verified by the officer concerned of this department on 28/01/2022 in the presence of Sh. Ravi Panth (Project Manager) and found that the building / premises is fit for the occupancy class "Educational" Group B with effect from 10/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 10/02/2022 at New Delhi.



(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal, Govt. Sarvodaya Vidyalaya Jai Dev Park (ID-1515001) located at Jai Dev Park, Punjabi Bagh New Delhi-110015.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.


09/02/2022

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Vidyalaya Jai Dev Park School Located at, Jai Dev Park, Punjabi Bagh New Delhi-110015. (School ID-1515001)
2. Type of Occupancy : Educational (Ground Floor + 03 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 28/01/2021
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Sh. Ravi Panth (Project Manager)
9. Year of Construction : 2021
10. Applicant's letter No. : 54 (SPS School)/PWD Edu. Sub- Divn M1-1(N)/2021-22/178 dated 27/12/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor			
	g. Door Size	1.5m	Provided	MR
		2 x 1.20 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N-10

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2021/666 dated 22/12/2021 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

~~D O (west)~~

Sarajeet Singh
ADO (MN)

09/ADD/MNS
01/02/2022

dy 02/02/2022

~~D CFO (W2)~~

D.O. (WEST) 377
DATED 2/2/2022

dy 08/02/2022

~~CFO~~

dy
1/2



dy 1/2/2022

~~D O (west)~~

dy 08/02/2022

ADO (MN)