

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2022/ 61

Dated: 10/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M.R Charitable trust Located at Sector – 10, Dwarka, New Delhi comprised of Ground +2 Upper Floors was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/2019/SZ/261 Dated 01/02/2019 The premises was re inspected by the officer concerned of this department on 24/01/2022 in the presence of Sh. Chander Shekher Jha (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 under DFS Act 2007, and that the premises is fit for occupancy class "Assembly Building" (Community Hall) with effect from 10/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on..... 10/02/2022at New Delhi by


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. Sh. Chander Shekher Jha (Manager) M.R Charitable trust Located at Sector – 10, Dwarka, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/7
INSPECTION REPORT

1. Name & address of the building: M.R Charitable trust Located at Sector – 10, Dwarka, New Delhi.
2. Type of Occupancy : Assembly (G + 2 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/2019/SZ/261 Dated 01/02/2019
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2003/2770 dated 11/11/2003
6. Date of inspection : 24-01-2022
7. Name of the Inspecting Officer : Udai vir Singh ADO/DWK
8. Name and designation of Officer
from the building side : Sh. Chander Shekher Jha (Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : 2021121928874 dated 20/12/2021

Ground & 1st Floor =Assembly Hall
Rooms (06)= 2nd floor

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/4	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr each	1.5 mtr & 01 mtr	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1.5 m	1.5m & 1m (Including door frame)	MR (Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per charge	Natural ventilation	MR

N/9

14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity 	50,000 litres	Provided	MR
	<ul style="list-style-type: none"> Draw off connection 	NA	NA	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	NA	NA
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	5,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 			
17.	Standby power supply	Required	DG Set	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Battery backup 	NA	NA	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/2019/SZ/261 Dated 01/02/2019 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *AOO/DWLP*

27/1/21

AOO/DWLP

Impd 01/02/2022

ay cfo (52)

F.T

AOO (DWLP)