

ESS

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/Banquet/WZ/2022/ 08

Dated: 11/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. Mosaic Banquet Located at Ground & First Floor, A-2, Wazirpur Ind. Area, New Delhi in a building comprised of Basement + Ground + 02 Upper Floors owned/occupied by M/s. Mosaic Banquet was issued Fire Safety Certificate by this department vide Letter No. F6/DFS/MS/Banquet/WZ/2019/378 dated 12.02.2019. The said premises was re-inspected by the officer concerned of this department on 05.04.2022 in the presence of Sh. Rajesh Gera (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Ground & First Floor only) with effect from 11/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/02/2022 at New Delhi by

(Dharampal Bhardwaj)
 Dy. Chief Fire Officer
 (West Zone)

Copy to:

1. The Addl. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.
3. Sh. Manish Tuli (Director), M/s. Mosaic Banquet Located at Ground & First Floor, A-2, Wazirpur Ind. Area, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expire.

INSPECTION REPORT

1. Name & address of the building: - M/s. Mosaic Banquet Hall Located at, **Ground & 1st Floor**, A-2, Wazirpur Industrial Area, New Delhi-110052.
2. Type of Occupancy : **Assembly at Ground Floor & 1st Floor** in a building comprised of Basement + Ground + 02 Upper floors.
3. Type of Case : Renewal
4. Details of previous NOC:- F6/DFS/MS/Banquet/WZ/2019/378 dated 12.02.2019
5. Fire Safety directives Letter No.:- F6/DFS/MS/BP/2010/3424 Dated-24/12/2010
6. Date of inspection : 05.04.2022
7. Name of the Inspecting Officer : S.P. Bhardwaj, Divisional Officer
8. Name and designation of Officer from the building side : Sh. Rajesh Gera (Manager)
9. Year of Construction : 2015
10. Applicant's online application no. 2022011800961 dated 18.01.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement/letter dated 12.02.2019	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12m	Provided	MR
	• Gate width	4.5mtr	On Road	MR
	• Width of internal road	As Per sanction plan	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2 m	2x2 m	MR
	• Basements	2x1.5 m	Provided(Including Railing & skirting)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x2 m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	nos.24 ABC & CO2	Provided Provided	MR MR

	<ul style="list-style-type: none"> Types IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Basement Required Required Appropriate places	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required NR NR	Provided Provided Provided	MR NR NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 2 2	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Required Required	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 lpm 60m Required 180 LPM 60m 2280 lpm 60 M Required Required 900 lpm 40M Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	50,000 ltrs. Required Required Required 25,000 ltrs.	1 lakh Ltrs. Provided Provided Provided Provided	MR MR MR MR MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Lift running from Ground floor to upper Floor)			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA NA Required Required Required	NA NA Provided Provided Provided	NA NA MR MR MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA

	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of fire safety certificate issued vide letter No. F6/DFS/MS/Banquet/WZ/2019/378 dated 12.02.2019 is recommended under the Delhi Fire Service rules 2010 under the DFS Act 2007.

Accordingly DFA is put up for approval & Sign please.

Sury
8/21/22
S.P. Bhardwaj
Divisional Officer

~~Def of WZ~~
~~Def of WZ~~
8/21/22

~~Def of Bhardwaj~~

FT is put up for signature please

~~Def of WZ~~
9/7/2022

Sury
8/21/22

ms/ceep