

C-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

No. F6/DFS/MS/School/WZ/2022 | 140

Dated: 10 / 02 / 2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Sarvodaya Kanya Vidyalaya (ID-1516018)(New Building)** located at **Moti Nagar New Delhi-110015**, comprised of Ground Floor + 03 Upper Floors owned/Occupied by **Govt. Sarvodaya Kanya Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and verified by the officer concerned of this department on 28/01/2022 in the presence of Sh. Ravi Panth (Project Manager) and found that the building / premises is fit for the occupancy class "**Educational**" **Group B** with effect from 10/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 10/02/2022 at New Delhi.


  
(Atul Garg)  
Director  
Delhi Fire Service

**Copy to:**

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya (ID-1516018) located at Moti Nagar New Delhi-110015.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

  
09/02/2022

**INSPECTION REPORT**

1. Name & address of the building : Sarvodaya Kanya Vidyalaya Moti Nagar New Delhi – 110015  
(School IS 15161018)
2. Type of Occupancy : Educational (Ground Floor + 03 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 28/01/2021
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers  
from the building side : Sh. Ravi Panth (Project Manager)
9. Year of Construction : 2021
10. Applicant's letter No. : 54 (SPS School)/PWD Edu. Sub- Divn M1-1(N)/2021-22/178  
dated 27/12/2021

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | BBL /NBC Requirement       | Provided at site | Remarks MR/NMR |
|--------|---|----------------------------|------------------|----------------|
| 1      | <b>Access to building</b>                                   |                            |                  |                |
|        | • Road width  | 6m                         | Provided         | MR             |
|        | • Gate width  | 4.5 m                      | Provided         | MR             |
|        | • Width of internal road                                    | NA                         | NA               | NA             |
| 2      | <b>Number, Width, Type &amp; Arrangement of Exits</b>       |                            |                  |                |
|        | a. Number of staircases                                     |                            |                  |                |
|        | • Upper Floors  | 2                          | Provided         | MR             |
|        | • Basements   | NA                         | NA               | NA             |
|        | b. Width of staircases                                      |                            |                  |                |
|        | • Upper Floors  | 1.5m each                  | Provided         | MR             |
|        | • Basements   | NA                         | NA               | NA             |
|        | c. Protection of exits                                      |                            |                  |                |
|        | • Fire check door   | NA                         | NA               | NA             |
|        | • Pressurization  | NA                         | NA               | NA             |
|        | e. No. of continuous staircases to terrace                  | NA                         | NA               | NA             |
|        | f. Width of Corridor  | 1.5m                       | Provided         | MR             |
|        | g. Door Size  | 2 x 1.20 m                 | Provided         | MR             |
| 3      | <b>Compartmentation.</b>                                    |                            |                  |                |
|        | • Fire check door   | NA                         | NA               | NA             |
|        | • Sealing of electrical shafts                              | NA                         | NA               | NA             |
|        | • Fire Rating of shaft door                                 | NA                         | NA               | NA             |
|        | • Water Curtain   | NA                         | NA               | NA             |
|        | • Fire Dampers  | NA                         | NA               | NA             |
| 4      | <b>Smoke Management System.</b>                             |                            |                  |                |
|        | • Basements   | NA                         | NA               | NA             |
|        | • Upper floors  | NA                         | NA               | NA             |
| 5      | <b>Fire Extinguishers</b>                                   |                            |                  |                |
|        | • Total numbers   | 12 nos.                    | Provided         | MR             |
|        | • Types   | CO <sub>2</sub> , ABC type | Provided         | MR             |
|        | • IS marking  | ISI marked                 | Provided         | MR             |

N-9

|    |  |             |          |    |
|----|--|-------------|----------|----|
| 6  | <b>First-Aid Hose Reels.</b>   |             |          |    |
|    | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>      | 2           | Provided | MR |
|    | <ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>         | 30 m        | Provided | MR |
|    | <ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>                  | 5 mm        | Provided | MR |
| 7  | <b>Automatic fire detection and alarming system.</b>                               |             |          |    |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> </ul>                | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>           | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>       | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>        | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>                | NA          | NA       | NA |
| 8  | <b>MOEFA</b>   | NA          | NA       | NA |
| 9  | <b>Public Address System.</b>  | NA          | NA       | NA |
| 10 | <b>Automatic Sprinkler System.</b>   |             |          |    |
|    | <ul style="list-style-type: none"> <li>Basement</li> </ul>                         | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Upper Floor</li> </ul>                      | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>    | NA          | NA       | NA |
| 11 | <b>Internal Hydrants</b>   |             |          |    |
|    | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>         | NR          | Provided | NR |
|    | <ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>     | NR          | Provided | NR |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | NR          | Provided | NR |
| 12 | <b>Yard Hydrants.</b>  |             |          |    |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>         | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | NA          | NA       | NA |
| 13 | <b>Pumping Arrangements.</b>   |             |          |    |
|    | <ul style="list-style-type: none"> <li>Ground Level</li> </ul>                     |             |          |    |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>         | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>              | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>           | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>            | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>               | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>           | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>              | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul> | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>              | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Terrace level</li> </ul>                    |             |          |    |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>              | 450 lpm     | Provided | MR |
|    | <ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>               | 40 m        | Provided | MR |
|    | <ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>                   | Required    | Provided | MR |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>          | Required    | Provided | MR |
| 14 | <b>Captive Water Storage for fire fighting.</b>                                    |             |          |    |
|    | <ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>        | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>            | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>             | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>                 | NA          | NA       | NA |
|    | <ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>           | 10,000 Ltrs | Provided | MR |
| 15 | <b>Exit Signage.</b>   | Required    | Provided | MR |

88

|    |  |    |    |    |
|----|--|----|----|----|
| 16 | <b>Provision of Lifts.</b>   |    |    |    |
|    | • Pressurization of Lift Shaft   | NA | NA | NA |
|    | • Pressurization of Lift lobby   | NA | NA | NA |
|    | • Communication In lift Car  | NA | NA | NA |
|    | • Fireman's Grounding Switch   | NA | NA | NA |
|    | • Lift Signage   | NA | NA | NA |
| 17 | <b>Standby power supply</b>  | NA | NA | NA |
| 18 | <b>Refuge Area.</b>  |    |    |    |
|    | ➤ Total Area   | NA | NA | NA |
|    | ➤ Location   | NA | NA | NA |
| 19 | <b>Fire Control Room</b>   |    |    |    |
|    | • Detector System Panel  | NA | NA | NA |
|    | • Flow Switch Panel  | NA | NA | NA |
|    | • PA System Panel  | NA | NA | NA |
|    | • Batter backup  | NA | NA | NA |
|    | • Building Floor Plans   | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/School/WZ/2021/673 dated 22/12/2021 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

~~D.O. (west)~~

Sarabjeet Singh  
ADO (MN)

08/ADD/mns  
01/02/2022

[Signature]  
02/02/2022

D.O. (WEST)/380  
DATED. 02/02/22

[Signature]  
27/2/2022

[Signature]

[Signature]  
4/2



[Signature]  
4/02/2022

[Signature]

[Signature]  
872  
AD2 (MN)