

C-39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F.6/DFS/MS/School/2022/SZ/ 167

Dated: 14/02/2022

FIRE SAFETY CERTIFICATE

Certified that the S.D.M.C Primary School, Nawada Main-II, Uttam Nagar, New Delhi-110059, comprised of ground plus two upper floors, owned/occupied by S.D.M.C Primary School have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 01/02/2022 in the presence of Smt. Savita (Principal) and found that the building is fit for occupancy "Educational Building" with effect from for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on..... 14/02/2022at New Delhi by


(Atul Gang)
Director
Delhi Fire Service
9/02/22

Copy to:-

1. The Principal,
S.D.M.C Primary School, Nawada Main-II,
Uttam Nagar, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/19

INSPECTION REPORT

1. Name & address of the building : S.D.M.C Primary School, Nawada Main-II, Uttam Nagar, New Delhi-59
 2. Building is comprised of : Ground plus two upper floors.
 3. Type of Occupancy : Educational
 4. Type of Case : New
 5. Details of Previous NOC : N/A
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 01/02/2022
 8. Name of Inspecting Officer : A.D.O. R.K.Yadav
 9. Name and designation of officers
 From the building side : Smt. Savita (Principal)
 10. Year of Construction : 2017
 11. Applicant's letter No. : Nil dated 24/01/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m N/A	09 m Provided N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s	02 no.'s	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	1.50 M	1.50 & 1.50 M	M/R
		N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		N/A	N/A	N/A
	e. Width of Corridor			
		N/A	N/A	N/A
	f. Door Size			
		Required	One	M/R
		1.50 M	2.10 M	M/R
		1.0 M	1.15 M (Double door)	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	07 no's ABC/CO ₂ type ISI marked	Provided	MR
			Provided	MR
			Provided	MR

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto-Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A 450 LPM 30 m Required Required	N/A Provided Provided Provided Provided	N/A MR MR MR MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 10000 ltrs	N/A N/A N/A N/A Provided	N/A N/A N/A N/A MR

4/21

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
				No Lift
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcoming was issued vide letter no.F.6/DFs/MS/School/2020/SZ/439 dated 30/04/2020 has been rectified. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R.K. Yadav
21/2/2022

Signature of Inspecting Officer
Name:- R.K.Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

R.K. Yadav
04/02/2022

By cfo (S)

[Signature]
4/2

CFO

del
9/2
[Signature]

And DR

