

E-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 144

Dated: 10/02/2022

FIRE SAFETY CERTIFICATE

Certified that the St. Joseph's Academy at Savita Vihar, Delhi-110092, comprised of basement, ground plus four upper floors owned/occupied by St. Joseph's Academy was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/963 dated 09/05/2018. The school building have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 02/02/2022 in the presence of Ms. Kochurani, Vice-Principal and that the building is fit for occupancy class "B" 'Educational Building' with effect from 10/02/2022 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on 10/02/2022 at New Delhi by


(Anil Garg)
Director
10/02/22

To,

The Principal,
St. Joseph's Academy,
Savita Vihar, Delhi-110092

Copy for information and necessary action, if any:-

1. The Commissioner,
EDMC, Headquarters,
419, Udyog Sadan, Patparganj Industrial Area,
New Delhi-110092
2. The Director of Education,
EDMC, 419, Udyog Sadan,
Patparganj Industrial Area,
Delhi-110092

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : St. Joseph Academy,
Savita Vihar, Delhi-110092
2. Building is comprised of : B+G+4 upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2018/NDZ/963
dated 09/05/2018
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 02/02/2022
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer
from the building side : Ms. Kochurani, Vice-Principal
10. Year of Construction : 1997
11. Applicant's letter No. : dated-07/01/2022

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	6 m	10 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	2 nos.	03 nos. (2+1)	MR
	• Basement	2 nos.	2 nos.	MR
	b. Width of Staircases			
	• Upper Floor	1.5 m	2 X 1.5 m & 1.2 m	MR
	• Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
	e. Width of Corridor	1.5 m	2.35 m	MR
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	17 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	• Total numbers on each floor	2 nos.	2 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose Box	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	900 LPM	900 LPM	MR
	• Head of the Pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 Ltrs.	25,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/13

		Required	Provided	MR
17	Standby power supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.


(Signature)
02/02/22
(Nagender Singh)
ADO (Shahdara)

Dy. CFO (NDZ)

(Signature)
7/2/22

CFO (NDZ)

- D/076



Director *(Signature)*
8/02/2022

D/076/NDZ

(Signature)
8/2/22

ADDC(S/NDZ) FT letter is placed for signatures please

ADDC(S/NDZ)

(Signature)
9/2/22

Director *(Signature)*
10/02/2022

M/Sen

(Signature)
8/2/22