

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/55

Dated: 08/02/2022

FIRE SAFETY CERTIFICATE

Certified that **The Laugh store (TLS Entertainment hub Pvt. Ltd)** located at **Shop No. 6, Fifth floor Vegas Mall, Sector – 14, Dwarka, New Delhi**, in a building comprised of 4 Basement + Ground + 11 Upper Floors (FSC issued to mall vide letter no F6/DFS/MS/2020/SZ/52 Dated 20/01/2020) owned/ occupied By **TLS Entertainment hub Pvt. Ltd** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 22/01/2022 in the presence of Sh. Anil Sobti and found that the said building that the premises is fit for occupancy class “ Assembly” Group D (Fifth Floor) with effect from 08/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/02/2022 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. Sh. Anil Sobti The Laugh store located at Shop No. 6, Fifth floor Vegas Mall, Sector – 14, Dwarka, New Delhi – 110078.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N19
INSPECTION REPORT

1. Name & address of the building: The Laugh store (TLS Entertainment hub Pvt. Ltd) located at Shop No. 6, Fifth floor Vegas Mall, Sector – 14, Dwarka, New Delhi – 110078.
2. Type of Occupancy : Class-D (Assembly) (At Fifth Floor in the Mall)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/2020/SZ/52 Dated 20/01/2020(issued to mall)
5. Fire Safety directives Letter No. :F6/DFS/MS/BP/2016/326 Dated 16/12/2016(issued to mall)
6. Date of inspection : 22/01/2022
7. Name of the Inspecting Officer ; DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Anil Sobti
9. Year of Construction :
10. Applicant's letter No. : 1366/Joint CP/Lic. (Amst) Dated, New Delhi, the 22/12/2021 & Email dated 19/01/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits(Common With Mall)			
	a. Number of staircases			
	• Upper floors	2	03 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided by Mall	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1.5m & 2m	Provided (Including door frame)	MR
3.	Compartmentation(Common With Mall)			
	• Fire check door	NA	Provided by Mall	NA
	• Sealing of electrical shafts	NA	Provided by Mall	NA
	• Fire Rating of shaft door	NA	Provided by Mall	NA
	• Water Curtain	NA	Provided by Mall	NA
	• Fire Dampers	NA	Provided by Mall	NA

14.	Captive water Storage for fire fighting: Common with Mall			
	<ul style="list-style-type: none"> Under ground tank capacity 	NA	400000 l (By Mall)	NA
	<ul style="list-style-type: none"> Draw off connection 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Fire service inlet 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Access to tank 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	20, 000 litres	Provided By Mall	MR
15	Exit Signage	Required	Provided By Mall	MR
16.	Provision of Lifts Common with Mall			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	Provided By Mall	NA
17.	Standby power supply	Required	Provided By Mall	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	Provided	NA
	<ul style="list-style-type: none"> Location 	6 th & 9 th Floor	Provided	NA
19.	Fire control room(Common with Mall)			
	<ul style="list-style-type: none"> Detector system panel 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Battery backup 	NA	Provided By Mall	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	Provided By Mall	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection.



Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

.....NIL.....

Signature of the Inspecting Officer
 Name: -Sh. D.B Mukherjee
 Designation: - DO/SW

Signature of the Inspecting Officer
 Name:- Sh. Udarvir Singh
 Designation ADO/DWK

dy cfo (S2)

 1/2

C.F.O.


 3/02/2022
 ADO/DWK

2/2/22
 1130