

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/2022/SZ/ 68

Dated: 15/02/2022

FIRE SAFETY CERTIFICATE

Certified that the **Dining Block**, AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of 2 Tiers Basement, Ground & Two Upper Floors, owned/occupied by All India Institute of Medical Sciences was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2014/SZ/1126 dated 04/09/2014. The premise was re-inspected by the officer concerned of this department on 03/02/2022 in the presence of Mr. Sudarshan Kumar Roa (EE) & his team and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly Group-D**" with effect from 15/02/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/02/2022 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Sh. Satyendra Kumar, Chief Security Officer, Administrative Block, All Institute of Medical Sciences, Ansari Nagar, New Delhi-110029
2. The Chief Architect, New Delhi Municipal Council, Palika Kendra, Sansad Marg, New Delhi-110001

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Dining Block at AHMS Complex, Ansari Nagar, New Delhi 110029		
2	Type of Occupancy	Assembly Building		
3	Building Comprised of	2 Tiers Basement, Ground & Two Upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	E.6/DFS/MS/2014/SZ/1126 dated 04/09/2014		
6	Fire Safety Directives Letter No	E.6/DFS/MS/BP/2013/214 dated 29/07/2014		
7	Date of Inspection	03/02/2022		
8	Name of the Inspecting Officers	DO (SD)		
9	Name & Designation of Officers from the building side	Mr. Sudarshan Kumar Roa (EE) & his team		
10	Year of construction	2013-14		
11	Applicant letter No.	E-mail dated 07/01/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9m 4.5m 6m	Provided Provided Provided	MR MR MR
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	02 Nos 02 Nos	Provided Provided	MR MR
	b. Width of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	2.0m 2.0m	Provided Provided	-NA- MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircase to terrace	Two	Provided	MR
	e. Width of corridor	2.0m	Provided	MR
	f. Door size	2.0m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	Required Required Required Required -NA-	Provided Provided Provided Provided -NA-	MR MR MR MR -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	Required Required	Provided -NA-	MR -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	30 Nos ISI marked	30 Nos. ABC & W.CO ₂ Provided	MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	Hose-reel	02 Nos 30m 5mm	MR MR MR

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors. 	Smoke/Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Each floor	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooter's location 	Each floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	02 Nos	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	02 Nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose box. 	Required	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2280, 2850 LPM	Provided	MR
	➤ Head of main pump.	65m	Provided	MR
	➤ Number of main pumps.	02 Nos	Provided	MR
	➤ Jockey Pump output.	180 & 280 LPM	Provided	MR
	➤ Jockey Pump head.	65m	Provided	MR
	➤ Standby Pump output.	2850 LPM (02)	Provided	MR
	➤ Standby Pump head.	65m	Provided	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Access to pump house	Required	N/A	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	900 LPM	-NA-
	➤ Head of pump.	-NA-	40m	-NA-
	➤ Power supply.	-NA-	Provided	-NA-
	➤ Auto starting of pump.	-NA-	Provided	-NA-
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	2,00,000 Lts	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	10,000 Ltr	-NA-	-NA-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	Required	Provided	MR
	<ul style="list-style-type: none"> Communication in lift car. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's switch. 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift signage. 	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any :	ABC & CO ₂ type fire extinguishers provided for HT/LT Panels		MR

The Fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/2014/SZ/1126 dated 04/09/2014, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S.K. Dua
07/02/20

Signature of the Inspecting Officer
 Name : S.K. Dua
 Designation: DO (SD)

DCFO (SZ)

[Handwritten signature]

[Handwritten signature]

F-7

D.C.F.O.

F.T. letter is put up for sig. pl.

DCFO (SZ)

[Handwritten signature]

S.K. Dua
10/02/20

M.S. Up