

c-7

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No. F6/DFS/MS/2022/EH/NDZ/ 36

Dated: 11/2/22

**FIRE SAFETY CERTIFICATE**

Certified that the Jubilant Food works Ltd.(Domino's Pizza) running on Ground floor, DMRC PD Area New Ashok Nagar Metro Station , Delhi-110096, the building is comprised of ground plus three upper floors, owned/occupied by Jubilant Food Works Ltd. (Domino's Pizza).The restaurants building was inspected by the officer concerned this department in the presence of Mrs. Karishma, Shift-Manager of the restaurant and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the eating house building is fit for ground floor occupancy class "D" 'Assembly Building' with effect from 11/2/22 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 11/2/22 at New Delhi by

  
(Atul Garg)  
Director

To,

The Manager  
Jubilant Food Works Ltd. (Domino's Pizza)  
16 seats, Ground & Mezzanine floor  
Dilshad Garden Metro Station.  
Delhi 110095

**MHA ID No. 2022011100615 dated:-12/1/22**

**Conditions for the validity of Fire Safety Certificate**

1. This NOC is valid for Ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : Jubilant Food works Ltd., (Domino's Pizza)  
G.F, DMRC PD Area New Ashok Nagar Metro  
Station, Delhi-110096
2. Building is comprised of : Ground Plus three upper floors  
(Restaurant on Ground floor only)
3. Type of Occupancy : Restaurant (Assembly)
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 20/1/2022
8. Name of the Inspecting officers : A.D.O. Mehmood
9. Name and designation of Officer  
from the building side : Ms. Karishma (Shift-Manager)
10. Year of Construction : 2008
11. Applicant's letter No : 2022011100615 Dated- 12/1/2022

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part- IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 mtr.	28 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 mtr & 1.50 mtr.	2.0 mtr, 1.50 mtr & 1.0 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	03 nos.	09 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

2/2

06	First-Aid-Hose Reels.			
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	Smoke/Heat	MR
	• Location of main panel	N/A	Provided	MR
	• Location of repeater panel	N/A	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	Near Gate	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Metro Station		
	• Discharge of main pump	1800 lpm	1800 lpm	MR
	• Head of main pump	70 mtrs	70 mtrs	MR
	• Number of main pumps	02 nos	04 nos. (2+2)	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	70 mtr	70 mtr	MR
	• Standby pump out put	1800 lpm	1800 lpm	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	Common with Metro Station			
	• Underground tank capacity	1,00,000 ltrs	1,00, 000 ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR



16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under NBC IV, it is recommended to issue Fire Safety Certificate under the rule 35 of Delhi Fire Service rules 2010.

*Mehmood*  
06/02/2022

Signature of the Inspecting Officer  
Name : Mehmood  
Designation : A.D.O.(T.P)

Dy.CFO(NDZ)

*Mehmood*  
7/2/22



CFO(NDZ) - D/O

Director

1 - If restaurant is on 9th floor then why this NOC is valid for 6th Mezzam floor. Pls check

2 -

Pl. inspect & put up.

*Mehmood*  
8/2/22

*Mehmood*  
8/2/22

DOCE) (with Join)

8-7-0