

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/WZ/2022/43

Dated: 15/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. **Nik Bakers, (A unit of MG Bakers Pvt. Ltd.)** Located at Plot No. 39, North West Avenue, Club Road, West Punjabi Bagh, New Delhi-110026 running at Ground floor only, in a building comprised of Ground floor, 1st floor, 2nd floor & 3rd floor, Owned/Occupied by **Nik Bakers, (A unit of MG Bakers Pvt. Ltd.)** was issued Fire Safety Certificate vide letter No. F6/DFS/MS/2018/WZ/2476 dated 02/11/2018, have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and verified by the officer concerned of this department on 10/02/2022 in the presence of Sh. Deepak Kumar Rawat and found that the said building is fit for occupancy class "Assembly" Group D with effect from 15/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions Mentioned Below.

Issued on 15/02/2022 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Owner/occupier M/s. **Nik Bakers, (A unit of MG Bakers Pvt. Ltd.)** Located at Plot No. 39, North West Avenue, Club Road, West Punjabi Bagh, New Delhi-110026 (**Reference: - ID No. 2022020101440 dated 04/02/2022**)
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (adlcp.lic-dl@nic.in)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowest_zone@gmail.com).

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. This NOC is valid for Ground floor only.

INSPECTION REPORT

1. Name & address of the building : Nik Bakers. (A unit of MG Bakers Pvt. Ltd.)Plot No. 39, North West Avenue, Club Road, West Punjabi Bagh, New Delhi-110026.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/WZ/2476 dated 02/11/2018
5. Fire Safety directives letter No : Nil
6. Date of inspection : 10/02/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO(MN)
8. Name and designation of officers from the building side : Sh. Sunil Rawat (Manager)
9. Year of Construction : 2001 (As per MHA portal)
10. Applicant's letter No. : Online Application No. 2022020101440 dated 04/02/2022

Note:- The said restaurant is running at Ground floor in a building comprised of Ground Plus Three upper floors.


S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement/As per prev. Insp. report dtd.- 29/10/2018	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 m	Provided	MR
		On Main Road	Provided	MR
		NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	NA	NA	NA
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
		NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	2m & 1 m	2m X 1, 1m X 1	MR being old case
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA

	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/EH/WZ/2022/152 dated 01/02/2022 have been complied.


Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter F6/ DFS/MS/2018/WZ/2476 dated 02/11/2018 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~DO (MS)~~



11/02/2022

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Asst. Divisional Officer (MN)

39/ADD/MN
14/02/2022



14/02/2022

~~DFS (WZ)~~


19/02/2022

As F. T is not up for your personal & signature
Please. 


~~DFS (WZ)~~


15/02/2022

15/02/2022

MSA CI

uploaded on MHA online portal.


17/02/22.