

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/42

Dated..15.02/2022

FIRE SAFETY CERTIFICATE

Certified that M/s Sapphire Foods India Ltd, (KFC Restaurants) located at Ground floor, Shop No DSS 24, 25, 26, 27, 28, 29 DLF South Square Mall, Sarojini Nagar, New Delhi-110023 in the building comprised of Basement, Ground plus Eight upper Floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 08/02/2022 in the presence of Mr. Madhu and that the premise is fit for occupancy class **Group-D Assembly Building (Restaurant at Ground Floor only)** with effect from 15/02/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 15/02/2022 at New Delhi by


**(ATUL GARG)
DIRECTOR / DFS**

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi- 110016 (Ref. MHA Portal ID 2022020301585 dated 03/02/2022)
2. M/s Sapphire Foods India Ltd, (KFC Restaurants) located at Ground floor, Shop No DSS 24, 25, 26, 27, 28, 29 DLF South Square Mall, Sarojini Nagar, New Delhi-110023.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

M/M

INSPECTION REPORT

1	Name & Address of the Building	M/s Sapphire Foods India Ltd, (KFC Restaurants) Shop No DSS 24, 25, 26, 27, 28, 29 DLF South Square Mall, Sarojini Nagar, New Delhi-110023.		
2	Type of Occupancy	Assembly Building "Group-D" Restaurant		
3	Building Comprised of	Basement, Ground plus Eight Upper Floors, Restaurant at Ground floor only.		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/Mixed/SZ/2021/317 dated 12/07/2021 for DLF South Square Mall, Sarojini Nagar.		
7	Date of Inspection	08/02/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Madhu		
10	Year of construction	2014		
11	Applicant letter No.	MHA Portal ID 2022020301585 dated 03/02/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	Access to Building. FSC No. F6/DFS/MS/Mixed/SZ/2021/317 dated 12/07/2021 for DLF South Square Mall, Sarojini Nagar.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Restaurant within Mall NA 	<ul style="list-style-type: none"> As above As above As above 	<ul style="list-style-type: none"> MR N/A N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> As above As above 	<ul style="list-style-type: none"> N/A N/A
	b. Width of Staircase	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> As above As above 	<ul style="list-style-type: none"> N/A N/A
	c. Protection of exits	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> N/A N/A 	<ul style="list-style-type: none"> As above As above 	<ul style="list-style-type: none"> N/A N/A
	d. No. of continuous staircase to terrace	07 Required	As above	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 No's Exit each 1.50 mtr	Provided	MR
3	Compartmentation.	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> Required Required 2 hrs N/A N/A 	<ul style="list-style-type: none"> As above As above Provided N/A N/A 	<ul style="list-style-type: none"> MR MR MR N/A N/A
4	Smoke Management system.	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> N/A Required 	<ul style="list-style-type: none"> As above Exhaust fans provided 	<ul style="list-style-type: none"> N/A MR
5	Fire Extinguishers.	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> 8 Nos ISI marked 	<ul style="list-style-type: none"> 08 Nos. ABC-04, W.CO₂-02 Provided 	<ul style="list-style-type: none"> MR MR MR
6	First Aid Hose Reels.	DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. 	<ul style="list-style-type: none"> Hose Reel 	<ul style="list-style-type: none"> 02 in Restaurant 30m 	<ul style="list-style-type: none"> MR MR

N/S

	• Nozzle Diameter		5mm	MR
7	Automatic Fire Detection and Alarming system. DLF South Square Mall, Sarojini Nagar			
	• Type of detectors	Required	Smoke & Heat	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR
8.	MOEFA	Required	As above	MR
9.	Public Address System	Required	As above	MR
10.	Automatic Sprinkler System	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	• Basement	Required	As above	MR
	• Upper floors	Required	Provided in Restt.	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	• Size of Riser/Down-comer	Required	As above	MR
	• Number of Hydrant per floor	Required	As above	MR
	• Hose box.	Required	As above	MR
12.	Yard Hydrants.	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	• Total number of hydrants.	N/A	As above	N/A
	• 2. Hose box.	N/A	As above	N/A
13.	Pumping arrangements.			
	• Ground Level	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	➤ Discharge of main pump.	2850 LPM	As above	MR
	➤ Head of main pump.	70 mtr	As above	MR
	➤ Number of main pumps.	Two	As above	MR
	➤ Jockey Pump output.	2 x 180 LPM	As above	MR
	➤ Jockey Pump head.	70 mtr	As above	MR
	➤ Standby Pump output.	2850 LPM	As above	MR
	➤ Standby Pump head.	70 mtr	As above	MR
	➤ Auto Starting / Manual Stopping.	Required	As above	MR
	➤ Access to pump house	Required	As above	MR
	• Terrace Level	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	➤ Discharge of pump.	900 LPM	As above	MR.
	➤ Head of pump.	40 m	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14.	Captive water storage for Fire Fighting.	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	• Underground tank capacity.	1,50,000 Ltrs	As above	MR
	➤ Draw-off connection.	Required	As above	MR
	➤ Fire Service Inlet.	Required	As above	MR
	➤ Access to tank.	Required	As above	MR
	• Overhead tank capacity.	25,000 Ltrs	As above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	• Pressurization of lift shaft.	Required	As above	MR
	• Pressurization of lift lobby.	Required	As above	MR

n/g

	<ul style="list-style-type: none"> • Communication in lift car. • Fireman's switch. • Lift signage. 	Required	As above	MR
		Required	As above	MR
		Required	As above	MR
17	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room.	Provided & Maintained by DLF South Square Mall, Sarojini Nagar		
	<ul style="list-style-type: none"> • Detector System Panel. • Flow Switch Panel. • PA system Panel. • Battery backup • Building floor plan 	Required	As above	MR
		Required	As above	MR
		Required	As above	MR
		Required	As above	MR
		Required	As above	MR
20.	Special Fire Protection System for the Protection of special Risk, if any :	Required	As above	MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

Ah
9/2/2022

Signature of the Inspecting Officer
Name: Rajesh Kumar
Designation: ADO / BCP

DO (SD)

King
9/2/22

Devi (SD)

[Signature]
10/2



[Signature]

[Signature]
14/2

[Signature]
19/2/2022
Anu BCP