## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI-110 001.

No.F.6/DFS/MS/School/2022/SZ/ | 89

Dated: 18/02/22

## FIRE SAFETY CERTIFICATE

Certified that the **S.D.M.C Primary School**, Jhatikra, New Delhi-110043 comprised of ground plus one upper floor, having total 12 rooms (Including Class Rooms, Office & Store etc.) owned/occupied by S.D.M.C was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2019/SZ/80 dated 09/01/2019. The school building was re- inspected by the officer concerned of this department on 29/01/2022 in the presence of Sh. Ram Diya (Principal) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

(SUNIL CHAWDHARY) DY.CHIEF FIRE OFFICER ⅔C€

Copy to:-

- The Principal, S.D.M.C Primary School, Jhatikra, New Delhi-110043
- Director of Education, S.D.M.C, Civic Centre, Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
- 3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4. The trained staff should be available round the clock.
- Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
- 8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

<b>~</b>		N/14					
2. 3. 4. 5. 6. 7. 8. 9.	Building Type of C Type of C Details of Fire Safe Date of in Name of Name an From the Year of C	comprised of:Ground plus ofccupancy:Educationalase:RenewalPrevious NOC:F.6/DFS/MS/Sy directives letter No:Circular No. F.16spection:29/01/2022Inspecting Officer:A.D.O. R.K.Y.d designation of officers:Sh. Ram Diyaonstruction:Before 2011	ary School, Jhatikra one upper floor only. School/2019/SZ/80 5/Estate/CC/Fire Safet adav	dated 09/01/2019 y/2011/3298 to 339			
S. No.		um Standards on fire prevention and ety U/R 33	Requirement	Provided at site	Remarks MR/NMR		
1.	Access	to building					
2.	• • •	Road width Gate width Width of internal road	06 m 4.5 m N/A	Provided Directly accessible from road N/A	MR MR N/A		
2.	Number, Width, Type & Arrangement of Exits						
	•	ber of staircases Upper Floors Basements	02 no.'s N/A	02 no.'s N/A	MR N/A		
	0. wid	th of staircases Upper Floor Basements	1.50 & .75 m	1.35& 1.35 m	MR N/A		
			N/A	N/A	IN/A		
	c. Prot	ection of exits Fire check door Pressurization	N/A N/A	N/A N/A	N/A N/A		
	d No	of continuous staircases to	N/A	N/A	N/A		
		ace	1.50 m	2.10 m	MR		
		dth of Corridor or Size	1.0 m	1.12 m (double door)	MR		
3.	Comp	artmentation					
	•	Fire check door	N/A	N/A	N/A		
		Sealing of electrical shafts Fire Rating of shaft door	N/A	N/A	N/A		
	•	Water Curtain	N/A	N/A	N/A		
	•	Fire Dampers	N/A N/A	N/A N/A	N/A N/A		
4.	Smoke Management System						
	•	Basements	N/A	N/A	N/A		
	•	Upper floors	Required	Natural Ventilation provided	MR		
5.	Fire E	xtinguishers		1			
		Tetel	05 No's	Provided	MR		
		Total numbers Types	ABC/CO <sub>2</sub> type	Provided	MR		
		IS marking	ISI marked	ISI marked	MR		

. . . .

N/15

6.	First-Aid Hose Reels						
	• Total numbers on each floor	N/A	N/A	N/A			
	<ul> <li>Length of hose reel hose</li> </ul>	$N/\Lambda$	N/A	N/A			
	Nozzle diameter	N/A	N/A	N/A			
7.	Automatic fire detection and alarming system						
	Type of detectors	N/A	N/A	N/A			
	<ul> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A			
	Location of Repeater Panel	N/A	N/A	N/A			
	<ul> <li>Alternate source of power</li> </ul>	N/A	N/A N/A	N/A N/A			
	<ul> <li>Hooters' Location</li> </ul>	N/A	N/A N/A	N/A N/A			
8.	MOEFA	N/A	N/A N/A	N/A N/A			
9.	Public Address System	N/A	N/A	N/A			
10.	Automatic Sprinkler System						
	Basement	N/A	N/A	N/A			
	Ground Floor	N/A	N/A N/A	N/A			
	<ul> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A			
11.	Internal Hydrants	1 V/FX					
	Size of riser/down-comer	N/A	N/A				
	• Number of hydrants per floor	N/A	N/A	N/A			
	Hose Box	N/A	N/A	N/A			
12.	Yard Hydrants	_ L					
	Total number of hydrants	N/A	N/A	N/A			
	Hose Box	N/A	N/A	N/A			
13.	Pumping Arrangements						
	Ground Level						
	Discharge of main Pump	N/A	N/A	N/A			
	Head of Main pump	N/A	N/A	N/A			
	Number of main pumps	N/A	N/A N/A	N/A N/A			
	Jockey Pump out put						
	<ul><li>Jockey pump head</li><li>Standby Pump out put</li></ul>	N/A	N/A	N/A			
	<ul> <li>Standby Pump out put</li> <li>Standby Pump Head</li> </ul>	N/A	N/A	N/A			
	<ul> <li>Auto Starting/Manual Stopping</li> </ul>	N/A	N/A	N/A			
		N/A	N/A	N/A			
		N/A	N/A	N/A			
	Pump House Access	N/A	N/A	N/A			
	Terrace level						
	<ul> <li>Discharge of pump</li> </ul>	N/A	N/A	N/A			
	<ul> <li>Head of the pump</li> </ul>	N/A	N/A	N/A			
	Power Supply	N/A	N/A	N/A			
	Auto Starting of pump	N/A	N/A	N/A			
14.	Captive Water Storage for fire fighting						
17.	Underground tank capacity	N/A	N/A	N/A			
	<ul> <li>Draw-off connection</li> </ul>	N/A	N/A	N/A			
	<ul> <li>Fire service inlet</li> </ul>						
	Access to tank	N/A	N/A	N/A			
	Overhead Tank capacity	N/A	N/A	N/A			
		N/A	N/A	N/A			
15.	Exit Signage.	N/A	N/A	N/A			

ıal afe <u>5Z/3</u> 98



## N/16

16.	Provisi	on of Lifts.		(	No Lift)		
10.	Pressurization of Lift Shaft		N/A	N/A	N/A		
	•	Pressurization of Lift lobby	N/A	N/A	N/A		
	•	Communication In lift Car	N/A	N/A	N/A		
	<ul><li>Fireman's Grounding Switch</li><li>Lift Signage</li></ul>	N/A	N/A	N/A			
		Lift Signage	N/A	N/A	N/A		
17.	Standb	y power supply	N/A	N/A	N/A		
18.	Refuge Area.						
	4	Total Area	N/A	N/A	N/A		
		Location	N/A	N/A	N/A		
19.	Fire Control Room						
	•	Detector System Panel	N/A	N/A	N/A		
	•	Flow Switch Panel	N/A	N/A	N/A		
	•	PA System Panel	N/A	N/A	N/A		
		Battery backup	N/A	N/A	N/A		
	Building Floor Plans	N/A	N/A	N/A			
20.	Special special	Fire Protection System for Protection of Risks, if any:	N/A	N/A	N/A		

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number <u>F.6/DFS/MS/School/2019/SZ/80</u> dated <u>09/01/2019</u> renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Signature of Inspecting Officer Name:- R.K.Yadav Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

04/02/2022

52)