

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/2022/SZ/ 79

Dated : 21/02/2022

FIRE SAFETY CERTIFICATE

Certified that the **Evergreen Sweet House** situated at **Plot No Y-48, Okhla Industrial Area, Phase-II, New Delhi 110020** comprised of Basement, Stilt + Ground floor + Two upper floors owned/occupied by Evergreen Sweet House was issued FSC by this department vide letter no F6/DFS/MS/G/SZ/2018/1768 dated 30/07/2018. The Premise was re- inspected by the officer concerned of this department on 15/02/2022 in the presence of Mr. Pankaj Bhardwaj found that the said Industrial building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and found that the said building / premises is fit for occupancy class **Group G "Industrial Building"** with effect from 21/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 21/02/2022 at New Delhi by



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)**

Copy to:

1. Mr. Manish Chopra, M/s Evergreen Sweet House at S-29 & 30, Green Park Main Market, New Delhi 110016.
2. The Executive Engineer (Building), SDMC, Jal Vihar, Lajpat Nagar, New Delhi 110024.

Conditions for the validity of the safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
2. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
3. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
4. Basement shall be used strictly as per Building Bye Laws.
5. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

- 1. Name & address of the building : Evergreen Sweet House, Plot No. Y-48, Okhla Industrial Area Phase-II, New Delhi-110020
- 2. Type of Occupancy : Industrial "Group-G"
- 3. Type of Case : Renewal [Basement, Stilt, Ground & 2 Upper Floors]
- 4. Details of Previous NOC : F6/DFS/MS/G/SZ/2018/1768 dated 30/07/2018
- 5. Fire Safety directives letter No : F6/DFS/MS/BP/2013/104 dated 03/06/2013
- 6. Date of inspection : 15/02/2022
- 7. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
- 8. Name and designation of officer from the building side : Mr. Pankaj Bhardwaj
- 9. Year of Construction : 2014
- 10. Applicant's letter No. : Gmail of dated 27/12/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12m 4.5m -NA-	Provided Provided -NA-	MR MR -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 Nos 2 Nos	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.5m 1.5m	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	2 Nos	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1m	1m (final exit)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required -NA- -NA- -NA-	Provided Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	M. V. Provided Ex. Fan Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Required ABC/W, CO ₂ / CO ₂ Required	20 Nos 10/10 Nos Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required Required -NA- Required Required	Smoke/Heat Ground Floor -NA- Provided All Levels	MR MR -NA- MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR

N/15

10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floors 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 Nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01 Nos	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02 Nos	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	02 Nos	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	2280 LPM	Provided	MR
		60m	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		60m	Provided	MR
		2280 LPM	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity 	1,00,000 Lts	Provided	MR
	<ul style="list-style-type: none"> Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 Lts	Provided	MR
15.	Exit Signage.			
		Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication In lift Car 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17.	Standby power supply			
		Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Flow Switch Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> PA System Panel 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Batter backup 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Building Floor Plans 	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			
		Required	Extinguisher Provided near electric panel	MR

2/16

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/G/SZ/2018/1768 dated 30/07/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

17/12/22

Signature of the Inspecting Officer

Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

DO (SD) - on maen

~~24/10/22~~

F.T.


ADO (B/P)

As approved, f.t. letter is put up for your signature pl

~~24/10/22~~



17/12/22

M.S. Upp