

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/NDZ/ 168

Dated: 15/02/2022

**FIRE SAFETY CERTIFICATE**


Certified that the Happy English School at Sharad Vihar, Karkardooma, Delhi-110092, comprised of ground plus two upper floors (temporary construction at third floor floor) owned/occupied by Happy English School was issued FSC vide letter No. F.6/DFS/MS/School/2019/NDZ/418 dated 18/02/2019. The Authorized signatory has given an undertaking dated 03/02/2022 not to use third floor for any other purpose. The school building have complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 16/12/2021 & 03/02/2022 in the presence of Sh. Mahesh Ranga, Administrative Head and that the building is fit for occupancy class "B" 'Educational Building' for ground plus two upper floor only with effect from 15/02/2022 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....15/02/2022.....at New Delhi by

**Note:- This Fire Safety Certificate does not include third floor.**

  
14/12/22

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer



To.

The Principal,  
Happy English School,  
Sharad Vihar, Karkardooma,  
Delhi-110092

Copy for information and necessary action, if any:-

1. The Commissioner,  
EDMC, Headquarters,  
419, Udyog Sadan, Patparganj Industrial Area,  
New Delhi-110092
2. The Joint Director of Education (Land & Estate),  
Directorate of Education, Lucknow Road,  
Delhi-110054

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/13

**INSPECTION REPORT**

1. Name & address of the building : Happy English School, Sharad Vihar, Karkardooma, Delhi-110092
2. Building is comprised of : G+2 (Temporary construction at third floor)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2019/NDZ/418 dated 18/02/2019
6. Fire Safety direction letter No : Delhi Fire Service Act 2007 and Rules 2010
7. Date of Inspection : 16/12/2021 & 03/02/2022
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Mahesh Ranga (Administrative Head)
10. Year of Construction : 1990
11. Applicant's email ID : hessharadvihar@gmail.com dt-17/11/2021

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	NBC-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	6 m	12 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	2 nos.	2 nos.	MR
	• Basement	N/A	N/A.	N/A
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.2 m each	MR(Accepted earlier)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers.			
	• Total numbers	11 nos.	11 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

2/14

06	First-aid-Hose Reels.			
	• Total numbers on each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	Provided	MR
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the Pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 Ltrs.	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures required under the rules and undertaking submitted by authorized signatory dated 03/02/2022 not to use third floor for any other purpose & sealed by school management, it is recommended to renewal Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

*(Signature)*  
 (Nagender Singh)  
 ADO (Shahdara)

Dy. CFO (NDZ) *1. Put up F.T.  
 2. PR speak.  
 (Signature) 7/2/22*

ADO (Shahdara) *1. Spoken  
 2. FT letter is placed for signatures please*

Dy CFO (NDZ) *(Signature) 14/2/22*

*(Signature)*  
 7/2/22

MS

