

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2022 | 184

Dated: 17/02/2022

FIRE SAFETY CERTIFICATE

Certified that the **Nigam Pratibha Vidyalaya**, Located at **Sri Nagar, New KeshavPuram Zone**, (School ID-1354017) Delhi – 110034 comprised of One Block (Ground + 2 Upper Floor Only) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2019/401 dated 13.02.2019. The said premises was re-inspected by the officer concerned of this department on 05.02.2022 in the presence of Ms. Rajbala Sharma (Principal) and found that the building / premises have deemed complied with fire prevention and fire safety requirements in accordance with D.O.E. Circular No. 3298 to 3398 dated 01.03.2011 and that the premises/building is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 17/02/22 for a period of **three years**, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/02/22 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Principal, Nigam PratibhaVidyalaya, Sri Nagar New KeshavPuramZone (School ID-1354017) Delhi.
2. The Director, Directorate of Education, Old Secretariat, Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the exits must be kept free from any obstructing.

INSPECTION REPORT

1. Name & address of the building: **Nigam Pratibha Vidyalaya**, Located at **Sri Nagar, New KeshavPuram Zone (School ID-1354017) Delhi – 110034**.
2. Type of Occupancy : Educational, One Block (Ground + 2 Upper Floor Only),
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2019/401 dated 13.02.2019
5. Fire Safety directives Letter No. : D.O.E circular dated 01/03/2011
6. Date of inspection : 05.02.2022
7. Name of the Inspecting Officer : S.P. Bhardwaj, DO
8. Name and designation of Officer from the building side : Ms. Rajbala (Principal)
9. Year of Construction : 1998
10. Applicant's letter No. : email dated 01.02.2022

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 1-3-11/letter dated 13.02.2019 | Provided at site | Remarks MR/NMR |
|------|---|--|--|--|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <ul style="list-style-type: none"> Accessible Accessible NA | <ul style="list-style-type: none"> Provided 370cm NA | <ul style="list-style-type: none"> MR MR(Old Case) NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 01 NA | <ul style="list-style-type: none"> 02 NA | <ul style="list-style-type: none"> MR NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 1.5m NA | <ul style="list-style-type: none"> 2x140cm NA | <ul style="list-style-type: none"> MR(Old Case) NA |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA |
| | d. No of continuous staircase to terrace | 01 | Provided | MR |
| | e. Width Of Corridor | 1.5m | 210cm | MR |
| | f. Door Size | 1m | 110cm,92cm (Double Door) | MR(Old Case) |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA |
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA | <ul style="list-style-type: none"> NA NA |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | <ul style="list-style-type: none"> 10nos. ABC & CO₂ ISI marked | <ul style="list-style-type: none"> Provided Provided Provided | <ul style="list-style-type: none"> MR MR MR |



| | | | | |
|----|--|-----------|----------|----|
| 6 | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | 02 | Provided | MR |
| | • Length of hose reel hose | 30m | Provided | MR |
| | • Nozzle diameter | 5mm | Provided | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System | NA | NA | NA |
| 10 | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants: | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm | Provided | MR |
| | ➤ Head of the pump | 40Mtr | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14 | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000Ltr | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E Circular no. 3298 to 3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2019/401 dated 13.02.2019 is recommended.

Satpal Bhardwaj
 Divisional Officer

D.O. (WEST) 348
 DATED.. 9/2/2022

~~*As/west*~~

~~*dy*~~ 09/2/2022

~~*Defo (W2)*~~

14/7 2022

~~*As Satpal*~~

FT is put up for signet for

~~*Defo W2*~~

16/7 2022

14/7 22