

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2022/ 84

Dated : 24/02/2022

FIRE SAFETY CERTIFICATE

Certified that the 54 Janpath, Connaught Place, New Delhi comprises of Basement + Ground + 03 Upper floor was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/2019/61 dated 08/01/19. Now, the premises was re-inspected by the officer concerned of this department on 17/02/22 in the presence of Mr. Amit Sangwan (Manager) and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Offices/Mercantile as above B + Gr. + 03 Upper floor with effect from - 24/02/2022 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 24/02/2022 at New Delhi by.


23/2/22

(Dr. S. K. Tomar)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. The Chief Architect , NDMC , Palika Kendra , New Delhi
2. The Manager,
John Tinson & Co. Pvt. Ltd.,
54, Janpath, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. The use of basement shall be as per BBL concerned.

N 121
INSPECTION REPORT

1. Name & address of the building 54, Janpath, Connaught Place New Delhi.
2. Type of occupancy:- Business /Mercantile Building
B + Gr. + 03 Upper floors,
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS /GH/2019/61 dated 08.01.2019
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/02/22
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC) &
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer
From the building side:- Sh. Amit Sangwan (Manager)
9. Year of construction:- Old Heritage Building
10. Applicant's letter No:- Nil dated 07/02/2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	12 mtr.	MR
	2) Gate width	N/A	N/A	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	02	02	MR
	B. Width of staircase			
	1. Upper floors	0.90 & 1.25 mtr.	0.90 mtr. & 1.25 mtr.	MR
	2. Basements	0.90 & 1.25 mtr.	0.90 mtr. & 1.25 mtr.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		01	01	01
	E. Width of corridor			
		N/A	N/A	N/A
	F. Door size			
		1.25 mtr.	1.25 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	Required	Provided	MR
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	Provided	MR

	2) Length of hose reel hose	30 mtr.	Provided	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 & 450 LPM	Provided	MR
	b) Head of pump	30 mtr.	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			

N/23

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & Co2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, the FSC issued vide letter no. F6/MS/DFS/2019/61 dated 08/01/2019, may be renewed under rule 35 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer


Signature of the Inspecting Officer

[Handwritten Signature]
22/2

[Handwritten Signature]
23/2/22

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Name :- Sh. Ravinder Singh
Designation : ADO (CC)



[Handwritten Signature]
23/2/22

ADO/CC

As approved, this permit is forwarded to the concerned authority for their perusal.

Dy. Commr. Fire

[Handwritten Signature]
23/2/22

[Handwritten Signature]
23/2/22

MS