

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/EH/2022/SZ/ 49

Dated: 23/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Bite Bikaner running at first floor of in a building comprised of basement, ground plus three upper floors located at C-1/1, First Floor, Janakpuri, New Delhi-110058, owned/occupied by Bite Bikaner restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 14/02/2022 in the presence of Sh. Rajesh Kumar Aggarwal (owner) and found that the building (**First Floor only**) is fit for occupancy 'Group D "Assembly Building"(Restaurant) with effect from 23/02/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.
Issued on..... 23/02/2022..... at New Delhi by


(Anil Garg)

Director
Delhi Fire Officer

9/9/22

To,

The Manager, M/s Bite Bikaner,
C-1/1, First Floor, Janakpuri, New Delhi-110058

Copy to:-

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station,
Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. This NOC is valid only for first floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per the building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

N/12

INSPECTION REPORT

1. Name & address of the building : M/s Bite Bikaner, C-1/1, First Floor, Janakpuri, New Delhi-110058.
2. Building is comprised of : G+3 upper floor but Restaurant is running at first floor only
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 14/02/2022
8. Name of the Inspecting Officers: : ADO R.K. Yadav & DO Vedpal Chhikara
9. Name of the designation of Officer from the building side : Sh. Rajesh Kumar Aggarwal
10. Year of Construction : 1989
11. Applicant's letter No : 2021123129718 dated 31/12/2021

S.No	Minimum Standards on fire safety requirements	NBC/UBBL 2005 & 1983	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	Provided	MR
	Gate width	N.A	N.A.	N.A.
	Width of internal road	N.A	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	2 no. .	Provided	MR
	Basement	N.A	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m each	1.50 m each	MR
	Basement	N.A	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A	N.A.	N.A.
	Pressurization	N.A	N.A.	N.A.
	e. No. of continuous staircases to terrace	Required	Provided	MR
	g. Width of Corridor	N.A	N.A.	N.A.
	h. No. of door	2 no.	2 no.	MR
	i. Door Size	1.5 M each	1.5M each	MR
3	Compartmentation.			
	Fire check door	N.A	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Provided	MR

M13

5.	Fire Extinguisher			
	Total numbers	04 no.	06 no.	MR
	types	ABC & CO ₂	ABC & CO ₂	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A.	N.A.
	Location of main panel	N.A	N.A.	N.A.
	Location of repeater panel	N.A	N.A.	N.A.
	Alternate source of power	N.A	N.A.	N.A.
	Hooters	N.A	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A	N.A.	N.A.
	upper floor	N.A	N.A.	N.A.
	sprinkler above false ceiling	N.A	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants each floor	1 no.	Provided	MR
	Hose box each floor	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	• Discharge of main Pump	N.A	N.A	N.A
	• Head of Main Pump	N.A	N.A	N.A
	• Number of main pumps	N.A	N.A	N.A
	• Jockey pump out put	N.A	N.A	N.A
	• Jockey pump head	N.A	N.A	N.A
	• Standby pump out put	N.A	N.A	N.A
	• Standby pump Head	N.A	N.A	N.A
	• Auto Starting /Manual stopping	N.A	N.A	N.A
	• Pump House Access			
	• Terrace Level	N.A	N.A	N.A
	• Discharge of pump			
	• Head of the Pump	450 LPM	Provided	MR
	• Power supply	40 M	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR

nc

h

13/14

14	Captive Water Storage for Fire Fighting			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	20,000 Liters	20,000 Liters	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A.	N.A.
	Pressurization of Lift lobby	N.A	N.A.	N.A.
	Communication in lift car	N.A	N.A.	N.A.
	Firemen's grounding switch	N.A	N.A.	N.A.
	Lift Signage	N.A	N.A.	N.A.
17	Standby power supply	N.A	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A	N.A.	N.A.
	Flow switch panel	N.A	N.A.	N.A.
	PA system panel	N.A	N.A.	N.A.
	Batter backup	N.A	N.A.	N.A.
	Building Floor Plans	N.A	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A.	N.A.


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued vide letter no. F6/DFS/MS/EH/2021/SZ/582 dated 21/12/2021 has been complied.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

The total covered area of the eating house at FF is 137.1 sq. meters. As per Part-IV, NBC-2016, Total the number of seats will come Approx. 76 (137.1 /1.8= 76.16) for the restaurant.

Signature of the Inspecting Officer
 Name :-R.K.Yadav
 Designation :-ADO(JKP)

Signature of the Inspecting Officer
 Name :- Vedpal Chhikara
 Designation :-DO(South West)



DCFO (SZ)
 17/12
 18/12

FT DS
 18/12/22