

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/2022/EH/NDZ/ 48

Dated 23/02/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Chintamani Food & Snacks Located at A-10 Jhilmil Ind. Area Shahdara, Delhi-110095 running on ground floor, the building is comprised Ground plus one upper floors owned/occupied by M/s Chintamani Food & Snacks. The restaurants building was re-inspected by the officer concerned this department in the presence of Mr. Aporva Sharma, Manager of the restaurant and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules 2010 and observed that the eating house building is fit for Ground floor occupancy class "D" 'Assembly Building' with effect from 23/02/2022 For a period of **three** years in accordance with the rules 36 unless renewed rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, Printed below.

Issued On 23/02/2022 at New Delhi by.



(A/10095/g)
Director
Delhi Fire Service
% 10

Copy To:-

The Manager
M/s Chintamani Food & Snacks.
A-10 Jhilmil Ind. Area
Shahdara, Delhi -110095.

MHA ID-2021082018394 Dated-25/08/2021

CONDITIONS For the validity of fire safety certificate

1. This NOC Valid for Ground floor only
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : M/s Chintamani Food & Snacks,
A-10 Jhilmil Ind.Area Shahdara, Delhi
2. Building is comprised of : Ground Plus one upper floors
(Restaurant on running on Ground Floor)
3. Type of Occupancy : Assembly Building
4. Type of Case : New
5. Details of Previous FSC letter No. : Nil
6. Fire Safety directive letter No. : NBC Part IV
7. Date of Inspection : 25/01/2022 & 10/02/2022
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Aporva Sharma, Owner
10. Year of Construction : 2000
11. Applicant's letter No : 2021082018394 dated 25/08/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 mtr. N/A N/A	15 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	N/A. N/A.	N/A. N/A	N/A N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	N/A N/A	N/A N/A	N/A N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. No of Exit	2nos.	2 nos.	MR
	f. Door Size	02 mtr.& 1.5 mtr.	02 mtr.& 1.80 mtr.	MR
03	Compartmentation.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 nos. ABC /CO ₂ ISI marked	08 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos	Provided	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos	01 nos	MR
	• Hose box	01 nos	01 nos	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	20,000 Ltr	20,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR

M/12

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings communicate earlier vide letter No F6/DFS/MS/EH/2021/191 dated 04/05/21 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under NBC IV, it is recommended to renewal Fire Safety Certificate under the rule 35 of Delhi Fire Service rules 2010.

Mehmood
10/21/2022
Signature of the Inspecting Officer
Name :- Mehmood
Designation :- A.D.O (T.P.)

Dy.CFO (NDZ) *Sir, I have also checked.*
Mehmood
11/2/22



CFO (NDZ) - D/O

Director / *where is the map of restriction?*
if bus paper is map by
1/10/22

D/O
Mehmood
11/2/22
ADDO Sir, the map is placed at e/f
May like to see please
Dy.CFO (NDZ) *Mehmood*
ADDO