

433

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/201


Dated:- 23/02/2022

FIRE SAFETY CERTIFICATE

Certified that the **EDMC Primary School** located at **A-2, Mayur Vihar, Phase-III, Delhi-96** comprised of **Ground + 01 Upper floor only (Old block only)**, owned/occupied by EDMC Primary School, was granted FSC by this department vide letter No. **F6/DFS/MS/School/2017/ NDZ/1876 dated 28/12/2017**. The premises was re-inspected by the officer concerned of this department on 14/02/2022 in the presence of the Mr. Madan Lal and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B “Educational Building” Sub-Div. B-I for Gr. + 01 upper floor only(Old block only)**, with effect from 23/02/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below subject to conditions printed below.

Issued on 23/02/2022 at New Delhi by.

Note:- This FSC does not include New Block.


(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92.
2. The Principal (1st shift),
EDMC Primary School, A-2, Mayur Vihar, Phase-III, Delhi - 110096.
3. The Principal (2nd shift),
EDMC Primary School, A-2, Mayur Vihar, Phase-III, Delhi - 110096.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building:- EDMC Primary School at A-2, Mayur Vihar, Phase-III, Delhi-96
2. Type of occupancy:- Educational Group **Gr.+01 Upper Floor**
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/NDZ/2017/1876 dated 28/12/2017
5. Fire safety directives No.- N/A
6. Date of inspection:- 14/02/2022
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. Madan Lal
9. Year of construction:- 1996
10. Applicant's letter No:- Email dated 18/09/2021.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	08 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	01	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr	1.5 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	1.5 mtr	1.5 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	04 Nos.	MR
	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A

2

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/1876 dated 28/12/2017, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
17/2/22

Name :- M.K. Sharma
Designation :- ADO (LN)

D.O (ED) *[Signature]*
18/02/2022

Dy. CFO (NDZ)

[Signature]
21/2/22

[Signature]

F.T. delhi is put up for sig. p

[Signature]
21/2/22

[Signature]
21/2/22

[Signature]

