

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2022/ 58

Dated: 03/03/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s. Barbeque Nation running at 3rd Floor in a building (Emaya Mall) comprised of basement, ground plus three upper floors located at Paschim Vihar, New Delhi-110034, owned/ occupied by M/s. Barbeque Nation Hospitality Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 14.02.2022 in the presence of Sh. Rajesh Kumar Mishra (Nodal Officer) and that the said Restaurant building is fit for occupancy class "Assembly" Group D (Restaurant at Third Floor only) with effect from 03/03/2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/03/2022 at New Delhi by


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
2. Sh. Kayum Razak, M/s. Barbeque Nation running at 3rd Floor, Emaya Mall, Paschim Vihar, New Delhi-110034.
3. The DHO, North Delhi Maniacal corporation, KesavPram Zone, New Delhi.

Following Fire Safety Directive must be adhered to:-

1. The FSC of restaurant is valid for Third Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s. Barbeque Nation, 3rd Floor, E Maya Mall, Paschim Vihar, New Delhi.
2. Type of Occupancy : Restaurant, Class-D (Assembly at Third Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : UBBL/NBC-Part IV
6. Date of inspection : 14.02.2022
7. Name of the Inspecting Officer : M.K. Chattopadhyaya, DO (West) & Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Rajesh Kumar Mishra, Nodal Officer
9. Year of Construction : 2000
10. Applicant's online application no. : 2022012301145
The restaurant is running at 3rd floor of a building comprised of basement, ground plus three upper floors (the building is granted FSC vide letter No. F6/DFS/MS/WZ/2019/1959 dated 15.10.2019).

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC-Part IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	NA
	• Width of internal road	06 m	Provided	MR
2.	Number, width, Type & Arrangements of exits- Provided by Mall			
	a. Number of staircases			
	• Upper floors	04	Provided	MR
	• Basements	NA	Rest. Running at TF	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	Provided	MR
	• Basements	NA	Rest. Running at TF	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 x 1.5 m	Provided	MR
3.	Compartmentation	Provided by Mall		
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System	Provided by Mall		
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 nos. type	Provided	MR
	• Types	ABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR


6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Provided by Mall		
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:	Provided by Mall		
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	04	Provided	MR
	• Hose Box	04	Provided	MR
12.	Yard Hydrants	Provided by Mall		
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements:	Provided by Mall		
	• Ground Level	NA	2280 LPM	NA
	• Discharge of main pump	NA	70 m	NA
	➤ Head of main pump	NA	01	NA
	➤ Number of main pumps	NA	180 LPM	NA
	➤ Jockey pump out put	NA	70 m	NA
	➤ Jockey pump head	NA	2280 LPM	NA
	➤ Standby Pump out put	NA	70 m	NA
	➤ Standby Pump Head	NA	Provided	NA
	➤ Auto Staring/Manual stopping	NA	Provided	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level	900 lpm	Provided	MR
	➤ Discharge of pump	50 m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:	Provided by Mall		
	• Underground tank capacity	NA	50,000 lts	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	25,000 lts	Terrace 15000, UG- 50000	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts	Provided by Mall		
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA


773


19.	Fire control room	Provided by Mall		
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of FSC is recommended under the rules 35 of the Delhi Fire Service Rules 2010 under the DFS Act 2007.


 M.K. Chattopadhyay
 DO (West)


 Aman Kumar Lathar
 ADO (JWP)


 CFO (122)


 24/12/22


O. (WEST) 2018
 DATED 17/12/2022

CFO




 25/12


 25/12/22

G/S Emaya Mall
 guarantee from this
 department

 25/12/22



 D.D. West

spoken. FSC of ~~Emaya~~ Emaya Mall (previous name Gourmet Hub/Capitol city mall) is valid upto 14.10.2022.

Submitted for approval please.


 Director


 D.D. West
 P.T.O


 02/13/2022
 put up system