

C-41

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/NDZ/ 228

Dated: 02/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that EDMC Pratibha Co-Ed. School at Jhilmil Colony, Delhi-110095, comprised of ground plus one upper floor owned/occupied by EDMC Pratibha Co-Ed. School was issued FSC vide letter No. F.6/DFS/MS/School/2019/NDZ/383 dated 12/02/19. The premises was re-inspected by the officer concerned of this department on dated 22/02/2022 in the presence of Mrs. Mamta Raj Arora (Teacher) and observed that all the fire prevent in and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational Building (Group-B)' with effect from 02/03/2022 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 02/03/2022 at New Delhi by

  
23/22

(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

O/c

To,

The Principal  
EDMC Pratibha Co-Ed. School at Jhilmil Colony, Delhi-110095

Copy:-

The Director of Education, EDMC  
Udyog Sadan, Plot No. 419, FIE, Patparganj Ind. Area, Delhi- 110092

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

14/17

1. Name & address of the building : EDMC Pratibha Co-Ed. School,  
Jhilmil Colony, Delhi-110095
2. Building is comprised of : Ground plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2019/NDZ/383 dated-12/02/19 ✓
6. Fire Safety direction letter No : F16/Estate/CC/Fire Safety/2011/3298to3398 ✓  
Dated -01/03/11(Director of Education)
7. Date of Inspection : 22/02/2022
8. Name of the Inspecting officers : ADC Deepak Kumar
9. Name and designation of Officer  
from the building side : Mrs Mamta Raj Arora (Teacher)
10. Year of Construction : 2001 & 2014
11. Applicant's letter No : D-243/EDMC PS/Jhilmil Colony 2022 dt-07/02/22

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	4.50 mtr	4.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	04 nos.	MR ✓
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr.	180 x2 mtr, 1.25mtr & 1.50 mtr.	MR ✓
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.50 mtr.	02 mtr.	MR ✓
	f. Door Size	01 mtr.	01 mtr.	MR ✓
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers			
	• Total numbers	06 nos.	10 nos.	MR
	• types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

7/19

16	Provision of Lifts.			
	• Pressurization of lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the circular No- F16/Estate/CC/Fire Safety/2011/3298to3398 dated-01/03/11 the FSC issued vide letter No. F6/DFS/MS/School/2019/NDZ/383 dated-12/02/19 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.



Signature of the Inspecting Officer  
 Name : Deepak Kumar  
 Designation : A.D.O (Shd)

~~DO(ED)~~ Pl. speak.

~~DO(ED)~~  
 23/02/2022

ASO (Shd)

Spoken and attended DPA is put up for signature pl.

~~DO(ED)~~  
 25/02/2022

Deepak  
 25/02/2022

Dy. CFSO (NDZ)  
 28/2/22

~~ASO(Shd)~~ FT letter is put up for signature please.  
 Deepak  
 02/03/2022