

c-36

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/2022/NDZ/ 230

Dated: 04 / 03 / 2022

**FIRE SAFETY CERTIFICATE**


Certified that the Prudence Junior School located at D-Block, Anand Vihar, Behind Water Tank, Delhi-110092 comprised of Basement, Stilt, Ground & Two Upper Floors owned / occupied by Adhunik Education Society has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/1653 dated 16/07/2018. The premises was re-inspected by the officer concerned of Fire Service on 18.02.2022 in the presence of Smt. Vinita Jha and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 04 / 03 / 2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 04 / 03 / 2022 at New Delhi by.

  
3/3/22

**(Dr. S.K.TOMAR)**  
**DY. CHIEF FIRE OFFICER**

Copy to :-

- 
1. Authorized signatory, Prudence Junior School, D-Block, Anand Vihar, Behind Water Tank, Delhi-110092.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.
8. Basement shall be used as per BBL-1983.

## INSPECTION REPORT

N/14

1. Name & address of the building: Prudence Junior School (Adhunik Education Society) D-Block, Anand Vihar, Behind Water Tank, Delhi-110092.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. F6/DFS/MS/School/2018/1653 dated 16/07/2018
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 18/02/2022
7. Name of the Inspecting Officer : DO (East)
8. Name and designation of Officer from the building side : Smt. Vinita Jha
9. Year of Construction : 2017
10. Applicant's letter email id anandvihar @prudenceonline.in dated 13/01/2022

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	NA
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	<b>a. Number of staircases</b>			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	02 nos.	MR
	<b>Width of staircases</b>			
	• Upper floors	1.50 m	1.50 m each	MR
	• Basements	1.50 m	1.50 m each	NA
	<b>Protection of exits</b>			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	02 nos.	02 nos.	MR
	c. Width Of Corridor	1.50 mtr	Provided	MR
	d. Door Size	1.00m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	Required (Basement)	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	10	20	MR
	• Types	ABC /Co <sub>2</sub>	Provided	MR
	• IS marking	ISI Marked	Provided	MR



6. First – Aid Hose Reels				
	• Total numbers on each floor	1 nos.	1 nos.	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7. Automatic fire detection and alarming system				
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10. Automatic Sprinkler System				
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11. Internal Hydrants				
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 no.	Provided	MR
	• Hose Box	1 no.	Provided	MR
12. Yard Hydrants				
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13. Pumping Arrangements				
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	1620LPM	1620LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14. Captive water Storage for fire fighting				
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr	MR


15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	ABC type fire extinguisher provide near electrical panel	NR

Note:-1. Shortcomings issued by this department vide letter no. F6/DFS/MS/School/2021/NDZ/688 dated 28/12/2021 have been complied.

2. General requirements for schools as per Director of Education circular dated 01/03/2011 / NBC (Part-IV)
1. Escape route .....:- Clear
  2. LPG cylinders in laboratories :- Nil
  3. Electric wiring .....:- Conduit Wiring MCB and ELCB.....  
Electric circuit .....:- MCB Provided
  4. Electric meter board / switch board panel.:-Not Under the staircase
  5. Basement use as per BBL 1983 :- Yes
  6. Emergency telephone no. board :- Displayed
  7. Generator set ..... :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/1653 dated 16/07/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Dy. SFO (NDZ)

*[Signature]*  
2/3/22

*[Signature]*  
28/02/22

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : D.O. (East)

DOCEB) As Approved, F.T. is added for Segm. Pl.

Dy. CFO (NDZ)

*[Signature]*  
3/3/22

*[Signature]*  
3/3/22