

C/38

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/SCHOOL/SZ/2022/ 205

Dated: 24/02/2022

**FIRE SAFETY CERTIFICATE**

Certified that the BGS International Public School, Located at Sec - 05, Dwarka, New Delhi - 110075 comprised of B + G + 3UF was issued FSC vide Letter No: F6/DFS/MS/School/2018/SZ/2332 Dated 16/10/2018. The premises was re inspected by the officer concerned of this department on 09/02/2022 in the presence of Sh. Bore Gowda (Administration) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Delhi Fire Service Rules 2010 under Delhi Fire Service Act 2007 and that the premises is fit for occupancy class "Educational" Group B with effect from 24/02/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/02/2022 at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. BGS International Public School, Located at Sec - 05, Dwarka, New Delhi - 110075

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

n/13

**INSPECTION REPORT**

1. Name & address of the building: BGS International Public School, Located at Sec – 05, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement, Ground+3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/School/2018/SZ/2332 Dated 16/10/2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2001/2733 Dated 24/12/2001
6. Date of inspection : 09-02-2022
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Bore Gowda (Administration)
9. Year of Construction : 2001
10. Applicant's letter No. : Email Dated 27/01/2022

Total Area = 16029 sqm.  
Covered Area = 6000 sqm  
Class rooms = 56  
No. of students = 2050

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/5	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (being old case)
	• Gate width	4.5 mtr	Old case	MR (being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.	05 Nos.	MR
	• Basements	02 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	Old case	MR (being old case)
	• Basements.	1.5 mtr each	Old case	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR (being old case)
	f. Door Size	01 mtr.	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR

*h*

N/14

5.	Fire Extinguishers				
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	25 nos. ABC & CO <sub>2</sub> ISI marked	Provided ABC & CO <sub>2</sub> ISI marked	MR MR MR	
6.	First - Aid Hose Reels				MR
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	03 30 05 mm	Provided Provided Provided	MR MR MR	
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA	
8.	MOEFA	NA	NA	NA	NA
9.	Public Address System	NA	Provided	NA	
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required NA NA	Provided NA NA	MR NA NA	
11.	Internal Hydrants:				
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100 mm 03 Nos. 03 Nos.	Provided Provided Provided	MR MR MR	
12.	Yard Hydrants				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA	
13.	Pumping Arrangements:				
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto starting/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	1620 lpm 40 mtr 01 No 180 lpm 40 mtr 1620 lpm 40 mtr Required Required 450 lpm 30 mtr Required Required	Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR MR	
14.	Captive water Storage for fire fighting:				
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	50,000 ltrs Required Required NA 20,000 ltrs	Provided Provided Provided Provided Provided	MR MR MR MR MR	
15	Exit Signage	Required	Provided	MR	MR

W



115

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	02 ABC type fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/2332 Dated 16/10/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*10/11/22*

Signature of the Inspecting Officer  
Name Udai Vir Singh  
Designation ADO/DWK

*D/SW* As per the approved building plan, only two staircases are required between basement and ground floor, therefore shalcoming of 3rd basement has been considered as deemed complied.  
Submitted please

*Dyefo (S2)*

*F.T.*

*MS*

*15/2/2022  
D.O(SW)*

*A DO DWK,*