

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2022 / WZ/206


Dated: 24/02/2022

FIRE SAFETY CERTIFICATE

Certified that Govt. Girls Secondary School (I.D No.1309036) located at Majlis Park, Delhi-110033 comprised of 02 blocks Interconnected- Ground & Ground + 01 upper floor owned/occupied by Govt. Girls Secondary School was granted FSC by this department vide letter No.F6/DFS/MS/2019/WZ/200 dated 28.01.2019. The premises was re-inspected by the officer concerned of this department on 08.02.2022 in presence of Smt. Bimla Devi Malik (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from 24/02/2022 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 24/02/2022 at New Delhi by


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707



Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Girls Secondary School, Majlis Park, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Secondary School, Majlis Park, Delhi-110033. (LD No.1309036)
2. Composition of building :02 blocks Interconnected of Ground & 01 upper Floors
3. Type of Occupancy :Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/D/FS/MS/2019/WZ/2000 dated 28.01.2019
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 08.02.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Smt. Bimla Devi Malik (Principal)
10. Year of Construction : 2008
11. Applicant's letter No. : Online E-Mail Dated 31.01.2022

Plot Area:980 Sqm	Covered Area:780 Sqm	Minimum Standards on Fire prevention and fire safety U/R 33	No. of Student:670	Circular of Director of Education	Provided at site	NO. of Class Room:10+6	Remarks MIR/MIR
1							
Access to building							
• Road width	6m	6m					MIR
• Gate width	4.5m	4.5m					MIR
• Width of internal road	NA	NA					NA
2							
Number, Width, Type & Arrangement of Exits							
a. Number of staircases							
• Upper Floors	02	02					MIR
Basements							
• Width of staircases	1.5m each	1.50m each					MIR
• Upper Floors	NA	NA					NA
Basements							
• Protection of exits	NA	NA					NA
• Fire check door	NA	NA					NA
• Pressurization	NA	NA					NA
d. No. of continuous staircases to terrace	1.5m	1.67m					MIR
e. Width of Corridor	1 m	98cm & 92cm					MIR(old case)
f. Door Size							
3							
Compartmentation.							
• Fire check door	NA	NA					NA
• Sealing of electrical shafts	NA	NA					NA
• Fire Rating of shaft door	NA	NA					NA
• Water Curtain	NA	NA					NA
• Fire Dampers	NA	NA					NA
4							
Smoke Management System.							
Basements							
• Upper floors	12 a/c per hour	NA					NA
Fire Extinguishers							
• Total numbers	10nos	11 nos					MIR

	<ul style="list-style-type: none"> Types ISI marking 	ABC/Co2	ABC-6 / Co2-5	MR
6	First-Aid Hose Reels.	ISI Marked	Yes	MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power. Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	N/A	NA
		NA	N/A	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.			

	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	N/A	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.200 dated 28.01.2019.

DO (N/A)

09/02/2022

By cfo (w2)

14/01/2022

Signature of the Inspecting Officer
 Name: - C.L. Meena
 Designation: - ADO/RN

09/02/2022

~~ADO/RN~~

As approved, F.T. letter is put up for your signature pl.

By cfo (w2)

24/01/2022

17/02/2022

use cell