

(32)

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2022/SZ/218

Dated: 28/02/2022


**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Girls Senior Secondary School No-3 located at Sarojini Nagar, New Delhi-110023 (ID-1719027) comprised of Ground + Two Upper Floor only owned / Occupied by Director of Education have been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/SZ/2722 dated 17/12/2018. The premises was re-inspected by the officer concerned of this department on 02.02.2022 in the presence of Sh. Brahmanand Vinod (State Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 28/02/2022 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 28/02/2022 at New Delhi by

  
(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)



Copy to: -

1. The HOS, Govt. Girls Senior Secondary School No-3, Sarojini Nagar, New Delhi-110023 (ID-1719027).
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).

## INSPECTION REPORT

N-20

1.	Name & address of the building	Govt. Girls Senior Secondary School No.-3, Sarojini Nagar, New Delhi-110023. (ID-1719027)		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	G + 2 upper floor		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2018/SZ/2722 dated 17/12/2018 For Ground + 1 <sup>st</sup> Floor only		
6.	Fire Safety directives Letter No	DOE Cir. Dated 01/03/2011		
7.	Date of Inspection	02.02.2022		
8.	Name of the Inspecting Officer	DO (SJ)		
9.	Name and Designation of Officer from the building side	Sh. Brahmanand Vinod (State Manager)		
10.	Year of Construction	1962		
11.	Applicant's letter received Email	GGSSSNo3/Misc/01/22 dated 25/01/2022		
S. No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	Two	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m / 0.75m	1.60m each	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One	MR
	e. Width Of Corridor	NA	1.5m	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	14 Nos	31 Nos.	MR
	• Types	ABC / CO <sub>2</sub>	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5cm	5cm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	100mm	NA
	• Number of hydrants per floor	NA	2	NA
	• Hose Box	NA	2	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltr	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA



N-22

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

- Note:-
1. Shortcomings issued by department vide letter No. F6/DFS/MS/2021/449 dated 01/09/2021 have been complied.
  2. General requirements for schools as per Director of Education circular dated 01/03/2011.
    1. Escape route .....:- **Clear**
    2. LPG cylinders in laboratories :- **Nil**
    3. Electric wiring .....:- **Conduit Wiring MCB and ELCB.....**  
Electric circuit .....:- **MCB Provided**
    4. Electric meter board .....:- **Not under staircase**
    5. Basement use as per BBL 1983 :- **N/A**
    6. Emergency telephone no. board :- **Displayed**
    7. Generator set ..... :- **NA**

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2018/SZ/2722 dated 17/12/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
3/2/2022

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: .DO (SJ)

DO (SD) *[Signature]*  
DeFO (SJ) *[Signature]*  
*[Signature]*

DO S.D *[Signature]*

DeFO (SJ) *[Signature]*  
F.T. letter is put up for sig. pl- *[Signature]*  
M.S. *[Signature]* *[Signature]*