

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F6/DFS/MS/School/2022 / w2/207

Dated: 24/02/2022

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Bal Vidyalaya (I.D No.1309001) located at C.C. Colony, Delhi-110007 comprised of 03 Blocks (01block, Ground +03 upper floors, 01 block, Ground+01upper floor & 01 block ground floor only) owned/ occupied by Govt. Sarvodaya Bal Vidyalaya was issued Fire Safety Certificated vide this office letter no. F-6/DFS/MS/School/2013/549 dated 11.07.2013. The premise was re-inspected by the officer concerned of this department on 08.02.2022 in the presence of Dr. Bijendra Kumar (Vice Principal) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under Educational "Group B" with effect from 24/02/2022 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 24/02/2022 at New Delhi


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Govt. Sarvodaya Bal Vidyalaya (I.D No.1309001) located at C.C. Colony, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doiit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

2/16

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Bal Vidhyalaya, C.C. Colony, Delhi -110007.
2. Composition of building : 03blocks (01 block. G+03 upper floors, 01 blocks- G+1 upper floors & 01 block Ground floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal.
5. Details of previous NOC : F.6/DFS/MS/School/2013/543 dated 11.07.2013
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011/ NBC Part-4
7. Date of inspection : 08.02.2022
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Dr. Bijendra Kumar (Vice Principal)
10. Year of Construction : 1991
11. Applicant's letter No. : Online E-mail I.D dated 04.02.2022

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06	18m	MR
	• Gate width	4.5m	5.2m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	04	MR
	• Upper Floors			
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	G+03 block -2.13m, 1.52m & G+01 block- 1.84m, 1.25m	MR
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	02	02	MR
	d. No. of continuous staircases to terrace	Required	2.17m	MR
	e. Width of Corridor			
	f. Door Size	01 m	01m double door each class	MR (old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	12 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

B

5	Fire Extinguishers			
	• Total numbers	20	20nos	MR
	• Types	ABC/Co2	ABC-20	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 (G+3 block)	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm (G+3 block)	Provided	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	(G+3 block)		
	➤ Discharge of pump	450lpm	450lpm x2	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. 2285 dated 24.05.2018

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. 549 dated 11.07.2013.

Do (MKT)

10/09/2022

24/07/2022

14/07/2022

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

ADO/RN

As approved, F.T. letter is setup for your signature pl.

17/02/2022

Cont...