

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI

No: F6/DFS/MS/Hosp/WZ/2022/ 98

Dated: 07/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **Acharya Bhikshu Hospital**, located at **Moti Nagar, New Delhi – 110015** comprised of Basement + Ground + 3 Upper Floors (100 Bedded), was issued FSC by this department vide Letter no. F6/DFS/MS/WZ/Hospital/2019/35 dated 07/01/2019. The premises was re inspected by the officer concerned of this department on 19/02/2022 in the presence of Sh. Rajeev Kumar, A.E (Civil) and found that the Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group C (Institutional) with effect from 07/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2022 at New Delhi.

(Dharampal Bhardwaj)
DY. Chief Fire Officer,
West Zone

Copy to:-

1. The Medical Superintendent, Acharya Bhikshu Hospital, located at Moti Nagar, New Delhi – 110015.
2. Assistant Engineer (E)-5, PWD HMESSD South West, Acharya Bhikshu Hospital, Moti Nagar New Delhi-110015.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Acharya Bikshu Hospital, Moti Nagar, new Delhi- 110015
2. Type of Occupancy : Institutional (Hospital)
3. Type of Case : Renewal (Basement + Ground + 3 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/WZ/HOSPITAL/2019/35 dated 07/01/2019
5. Fire Safety directives letter No : F6/DFS/MS/BP/Hospital/2001/193 dated 29/01/2001
6. Date of inspection : 19/02/2022
7. Name of the Inspecting Officers : Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side : Sh. Rajeev Kumar, A.E(Civil)
9. Year of Construction :
10. Applicant's letter No. : Email dated: - 11/02/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 mts	11.5 mts Provided	MR
		5 mts	Provided	MR
		Required	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	06 stairs + 01 ramp	Provided	MR
		06	Provided	MR
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 mts	4 x190 cm, 1x140cm, 1x150 cm & ramp 255 cm	MR (old case)
		2 mts	4 x190 cm, 1x140cm, 1x150 cm & ramp 255 cm	MR (old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required	Provided	MR
		NA	NA	NA
	e. No. of continuous staircases to terrace	02	Provided	MR
	f. Width of Corridor	Required	280cm Provided	MR
	g. Door Size	Required	197cm Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
		NR	NR	NR
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	Required	Provided	MR
		Required	Openable window provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	50 nos. CO ₂ , ABC type ISI marked	Provided	MR
			Provided	MR
			Provided	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	04 on each floor	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 mts	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Smoke & Heat	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	03	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	2850 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Head of Main pump 	60 mts	Provided	MR
	<ul style="list-style-type: none"> ➤ Number of main pumps 	02	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	180 LPM	Provided	MR
	<ul style="list-style-type: none"> ➤ Jockey pump head 	60 mts	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	2850 mts	Provided	MR
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	60 mts	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NR	NR	NR
	<ul style="list-style-type: none"> ➤ Head of the pump 	NR	NR	NR
	<ul style="list-style-type: none"> ➤ Power Supply 	NR	NR	NR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NR	NR	NR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	2,00,000 ltr	Provided	MR
	<ul style="list-style-type: none"> ➤ Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	30,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

88

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NR	Provided	NR
		NR	NR	NR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NR	NR	NR
		NR	NR	NR
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter no.F6/DFS/MS/WZ/HOSPITAL/2019/35 dated 07/01/2019 renewal under rule 35of the Delhi Fire Service Rules 2010 is recommended.

~~No (must)~~

[Signature]
19/04/2022

Signature of the Inspecting
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Signature]
21/02/2022

~~DCFO (WZ)~~

[Signature]
24/07/2022

~~ADSO/ M.C.N~~

F.T is put up for your perusal & signature
Please.

[Signature]
4/07/2022

[Signature]

must call