

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/Audi./2022/SZ/ 97

Dated: 07/03/2022


FIRE SAFETY CERTIFICATE

Certified that M/s Air Force Auditorium at Subroto Park, Delhi Cantt. New Delhi-110010, comprised of basement, ground plus one upper floor, Auditorium at ground floor only without balcony & basement totally separate, owned/occupied by Indian Air Force was issued FSC by this department vide letter No. F.6/DFS/MS/Auditorium/2019/SZ/651 dated 27/03/2019. The premise was re-inspected by the officers concerned of this department on 21/02/2022 in the presence of Group Capt. Manoj Mehta (Director, AF Auditorium) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group 'D' Assembly Building**" (Auditorium) with effect from 07/03/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/03/2022 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. Group Capt. Manoj Mehta (Director, Air Force Auditorium), Subroto Park, Delhi Cantt. New Delhi-110010
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Air Force Auditorium, Subroto Park, Delhi Cantt., New Delhi- 110010		
2	Type of Occupancy	Group 'D' Assembly Building		
3	Building Comprised of	B+G+01 upper floor. (Audi at Ground Floor only without balcony & basement is totally separate)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Auditorium/2019/SZ/651 Dt. 27/03/2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	21/02/2022		
8	Name of the Inspecting Officers	DO (SD) & ADO (M. Road)		
9	Name & Designation of Officers from the building side	Group Capt. Manoj Mehta (Director, AF Auditorium)		
10	Year of construction	1990		
11	Applicant letter No.	Outdoor Diary No. 6377 Dated 09/02/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors	4 Nos	4 Nos for seats at higher level	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b. Width of Staircase			
	➤ Upper floors	1.5m	1.8m, 1.9m, 1m & 1m	MR (Old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1m	Provided 08 Nos	MR (Old case)
3	Compartmentation.			
	• Fire check door.	Required	Provided in basement	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	Exhaust Fans	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	38 Nos	MR
	• Types	ABC / CO ₂	ABC, CO ₂ , & W CO ₂	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	5 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.	• Type of detectors	Required	Smoke type	MR		
		• Location of Main Panel	Required	Fire Control Room	MR		
		• Location of Repeater Panel	-NA-	-NA-	-NA-		
		• Alternate source of power	Required	Battery backup	MR		
		• Hooter's location	Required	Provided	MR		
8.	MOEFA		Required	Provided	MR		
9.	Public Address System		-NA-	-NA-	-NA-		
10.	Automatic Sprinkler System						
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 		-NA-	-NA-	-NA-		
			Required	Provided	MR		
			-NA-	-NA-	-NA-		
11.	Internal Hydrants.						
	<ul style="list-style-type: none"> • Size of Riser/Down-comer • Number of Hydrant per floor • Hose box. 		-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
12.	Yard Hydrants.						
	<ul style="list-style-type: none"> • Total number of hydrants. • Hose box. 		08 Nos	Provided	MR		
			08 Nos	Provided	MR		
13.	Pumping arrangements.						
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual stopping. ➤ Pump house access. • Terrace Level <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. 		1620 LPM	1620 LPM	MR		
			70m	70m	MR		
			One	One	MR		
			240 LPM	240 LPM	MR		
			70m	60m	MR (old case)		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			Required	Provided	MR		
			Required	Provided	MR		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
		14.	Captive water storage for Fire Fighting.				
			<ul style="list-style-type: none"> • Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. • Overhead tank capacity. 		1,00,000 Ltrs	Provided	MR
	Required			Provided	MR		
	Required			Provided	MR		
	Required			Provided	MR		
	10,000 Ltrs			Provided	MR		
	Required			Provided	MR		
15.	Exit Signage.						
16.	Provision of Lifts.						
	<ul style="list-style-type: none"> • Pressurization of lift shaft. • Pressurization of lift lobby. • Communication in lift car. • Fireman's switch. • Lift signage. 		-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		
17	Standby Power Supply		Required	Provided	MR		
18.	Refuge Area						
	<ul style="list-style-type: none"> • Total area • Location 		-NA-	-NA-	-NA-		
			-NA-	-NA-	-NA-		

19.	Fire Control Room.			
	• Detector System Panel.	Required	Provided	MR
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any:	-NA-	-NA-	-NA-

The fire protection system provided in the building/premises were checked, tested at random and found functional at the time of inspection. Eight doors of more than one meter width found provided in the main Hall of Auditorium. However additional exits are provided in the Foyer area and back stage (direct exit) area also.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the fire safety certificate issued vide letter No. F.6/DFS/MS/Auditorium/2019/SZ/651 dated 27/03/2019, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S.K. Dua
25/3/22

Signature of the Inspecting Officer
Name : S.K. Dua
Designation: DO (SD)

Rajesh Kumar Shukla
25/3/22

Signature of the Inspecting Officer
Name: Rajesh Kumar Shukla
Designation: ADO (M. Road)

DCFO (SZ)

F.T.
[Signature]

ADO (B/P)

Area of jurisdiction under SJ sub Division, and the inspection was conducted by Jointly. Hence, the file is being forwarded to DO/SD for further n/a pl.

1/14
4/3/22

DO/SD

F.T. letter is put up for sig. pl.

Defg(sz)
[Signature]

[Signature]

M.S. [Signature]

S.K. Dua
25/3/22