

C-43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/NDZ/2022/ 61

Dated : 09/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/S The Host Restaurant ( A Unit of Kolmet Enterprises ) located at F-8 , Inner circle, Connaught Place, New Delhi comprises of Ground + mez. and 02 upper floors, restaurant at ground and mezzanine floor only, was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/2019/NDZ/914 dated 30/04/19. Now, the premises was re-inspected by the officers concerned of this department on 04/03/22 in the presence of Manager and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D Restaurant at ground and mezzanine floor only** with effect from .....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 09/03/2022 at New Delhi by.

  
(Dr. S.K. Tomar )  
Dy. Chief Fire officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi Online id 2022011000559 dated 11.01.22& email dated [patwalsunny@gmail.com](mailto:patwalsunny@gmail.com). Dated 28.02.2022.
2. The Medical Officer of Health, Health Department, Palika Kendra, New Delhi.
3. The Manager,  
The Host Restaurant (A Unit of Kolmet Enterprises) located at F-8, Connaught Place, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

#1116  
INSPECTION REPORT

1. Name & address of the building      The Host Restaurant, A Unit of Kolmet Enterprises) F-8, Inner circle Connaught Place New Delhi -110001
2. Type of occupancy:-                      Assembly Building Group-D  
Group Assembly Building Gr.+mez.+2 upper Floor (Rest. At Gr.& Mezzanine Floor)
3. Type of case:-                              Renewal
4. Details of previous FSC:-                F6/DFS/MS/EH/NDZ/2019/914 dated 30.04.2019
5. Fire safety directives No.-                N/A
6. Date of inspection:-                      04/03/22
7. Name of the inspecting officer:-        Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:-                    Manager
9. Year of construction:-                    1977
10. Applicant's letter No:-                    Online id 2022011000559 dated 11.01.22& email dated patwalsunny@gmail.com dated 28.02.2022

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	6.0mtr	06 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	1. Upper floors	02nos	02 nos	MR
	2. Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	1. Upper floors	1.25 & 0.75 mtrs	1.30 & 0.75mtrs	MR
	2. Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>			
	N/A			
	<b>E. Width of corridor</b>			
	N/A			
	<b>F. Door size</b>			
	1.5 mtr		02 mtrs, 1.5m	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	05 Nos.	06 Nos.	MR

✓

4/17

	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	provided	MR
	2) Length of hose reel hose	30 mtr.	30 M	MR
	3) Nozzle diameter	05 mm	05 MM	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Provided	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	900 LPM	900 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A



21/18

	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltr.	provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


In view of deemed compliance of fire safety measures as required under Rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2019/NDZ/914 dated 30/04/19, under rule 35 of the Delhi Fire Service rules 2010. Accordingly, FSC letter is prepared and put up for kind perusal and approval & signature please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name:- Rajinder Atwal  
Designation:-DO(CD)

Name:- Sh. Ravinder Singh  
Designation:- ADO (CC)



Dy. FSC (ND2)

Pl. speak

Rajinder  
8/3/22

DO (CC)

1. Spoken on 8/3/22.
2. Resubmitted, please

Rajinder  
8/3/22

Dy. FSC (ND2)

Rajinder  
8/3/22

ADO (CC)

As approved, DTY put up for new FSC and separation please

Rajinder  
9/3/22

Dy. FSC (ND2)

Rajinder  
9/3/22