

C-53

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

F6/DFS/MS/GH/NDZ/2022/141

Dated: 09/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Azmi Hostel located at 198, Gali Garahiya, Matia Mahal, Jama masjid, Delhi, comprised of **Ground + Mezzanine + 03 upper floors: Ground floor** – reception + 1 dormitory with 04 beds, **Mezzanine** – (01 store room), **1<sup>st</sup> floor** - 1 dormitory with 03 beds + office, **2<sup>nd</sup> floor**- 1 dormitory with 04 beds + small store room, **3<sup>rd</sup> floor**- 1 dormitory with 04 beds + small store room, **total 04 dormitory (hall) with 15 beds** was granted FSC by this department vide letter no. F6/DFS/MS/GH/NDZ/2018/888 dated 03.05.2018. The building/premises was re-inspected by Assistant Divisional Officer (SPM) from this department on 24.02.2022 in presence of Mr. Irfan Ahmed, Owner and found that the building is comprised of ground + Mezzanine + 03 upper floors and now the floor wise occupancy is **Ground floor** – reception + 1 dormitory with 04 beds, store room, **Mezzanine** – (01 store room), **1<sup>st</sup> floor** - 1 dormitory with 03 beds + office, **2<sup>nd</sup> floor**- 1 dormitory with 04 beds + small store room, **3<sup>rd</sup> floor**- **not in use as per undertaking dated 28.02.2022**. The building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of **“Residential Sub Division-A-1** for total **03 dormitory (hall) with 11 beds (Ground floor** – 1 dormitory with 04 beds, **1<sup>st</sup> floor** - 1 dormitory with 03 beds, **2<sup>nd</sup> floor**- 1 dormitory with 04 beds, with effect from 09/03/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 09/03/2022 at New Delhi by

(Dr. S.K. Tomar)  
8/3/22

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Tel: 011-23412025

**Copy to:-**

1. The Commissioner, North Delhi Municipal Corporation, S.P.M, Civic Centre, New Delhi: - to ensure the occupancy as detailed above.
2. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi: - Ref. MHA Portal ID. No. 2022010600370 dated 6.01.2022 & Email dated 07/02/2022.
3. The Licensee, M/s Azmi Hostel located at 198, Gali Garahiya, Matia Mahal, Jama masjid, Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
8. The occupancy of 4<sup>th</sup> floor not allowed as per clause 7.31 in UBBL-2016.

be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

- 8 The occupancy of 4<sup>th</sup> floor not allowed as per clause 7.31 in UBBL-2016.

INSPECTION REPORT	
1.	Name and address of the building: <b>M/s Azmi Hostel located at 198, Gali Garahiya, Matia Mahal, Jama masjid, Delhi-06.</b>
2.	Type of occupancy with details of floors: <b>Residential Sub Division- A-1 (Ground +Mezz. + 02 Upper floors)</b> <b>Ground floor</b> – reception + 1 dormitory with 04 beds <b>Mezzanine - 01</b> store room <b>1<sup>st</sup> floor</b> - 1 dormitory with 03 beds + office <b>2<sup>nd</sup> floor-</b> 1 dormitory with 04 beds + small store room (Total 03 Dormitory (Hall) with 11 Bed) <b>3<sup>rd</sup> floor-</b> not in use (Affidavit attached)
3.	Type of case: Renewal case
4.	Details of previous FSC: F6/DFS/MS/GH/NDZ/2018/888 dated 03.05.2018
5.	Fire safety directives no.: NA
6.	Date of inspection: 24.02.2022
7.	Name of the inspecting officer: Sumit Kumar, ADO (SPM)
8.	Name and designation of the officer from the building side: Mr. Irfan Ahmed, Owner
9.	Year of construction: Old
10.	Reference letter no.: Online application I.D. 2022010600370 dated 6.01.2022 & Email of Dated 07/02/2022

S,N o	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (Existing Fire & Safety Measures)	Provide at site (PSS)	Remarks MR/NMR
1	<b>Access to Building</b>			
	A Road width	NA	3 mtrs.	NA
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	A <b>No. of Staircase:</b>			
	a) Upper floor	01 nos.	01 nos.	MR
	b) Basements	NA	NA	NA
	B <b>Width of the Staircase:</b>			
	a) Upper floors	0.80 mtrs.	0.81 mtrs.	MR
	b) Basements	NA	NA	NA
	C <b>Protection of Exits</b>			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D <b>No. of continuous staircase to terrace:</b>	01 nos.	01 nos.	MR
	E <b>Width of the corridor</b>	NA	NA	NA
	F <b>Door size</b>	1 mtrs.	1 mtrs.	MR
	<b>Compartmentation:</b>			
	A Fire check doors	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
	<b>Smoke Management System:</b>			
	A Upper floors	Natural/ mechanical	Natural	MR
	B Basements	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	A Total numbers	06 no.	06 no.	MR
	B Types	CO2 , ABC	CO2, ABC	MR
	C ISI marking	Required	Provided	MR




6	<b>First Aid Hose Reel</b>				
	A	Total no. at each floor	Ground & 2 <sup>nd</sup> floor	Ground & 2 <sup>nd</sup> floor	MR
	B	Length of hose reel	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05mm	MR
7	<b>Automatic Fire Detection and Alarm System (ADAS)</b>				
	A	Type of detectors -(CO) detector	CO detectors (required as per GN dated 27.05.2019)	Provided	MR
	B	Location of main Panel	At reception	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power Source	Required	Provided	MR
	E	Hooter's location	Audible in entire building.	Provided	MR
8	<b>MOEFA</b>				
9	<b>Public Address System</b>				
			Required	Provided	MR
10	<b>Automatic Sprinkler System</b>				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>				
	A	Size of the riser/down comer	NA	NA	NA
	B	No. of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	<b>Yard Hydrants</b>				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	<b>Pumping Arrangements</b>				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) Discharge of jockey pump	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Discharge of standby pump	NA	NA	NA
		g) Head of standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	225 LPM	225 LPM	MR
		b) Head of terrace pump	35 mtrs.	35 mtrs.	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for Fire Fighting</b>				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	2500 ltr.	2500 ltr.	MR
	D	Overhead tank capacity	Required	Provided	MR
15	<b>Exit Signage</b>				
16	<b>Provision of lift</b>				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	Required	Provided	MR
17	<b>Standby Power Supply</b>				


<b>18 Refuge Area</b>				
A	location	NA	NA	NA
B	Total area	NA	NA	NA
<b>19 Fire Control Room</b>				
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
<b>20 Special Fire Protection for special risk if any</b>				NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2018/888 dated 03.05.2018 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

  
 Signature of the Inspecting Officer  
 Name: - Sh. Sumit Kumar  
 Designation ADO (SPM)

DO (CD)


  
3/3/22

Dy CRO (ND2)


  
4/3/22

ADQ/SPM

F.T. letter is put up for Signature, Please.

  
07/03/2022

Dy CRO (ND2)

  
8/3/22

MS

