

C-78

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2022/60

Dated 08/03/2022

FIRE SAFETY CERTIFICATE

Certified that **M/s Bikanervala Foods Pvt Ltd.** located at Property No 14 & 15, Community Centre, Malviya Nagar Extension, Saket, New Delhi 110017 comprised of Basement, ground plus Three Upper floors but **restaurant running at Ground & First Floor only**. Owned/occupied by Mr. Ashok Kumar Aggarwal was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2019/SZ/648 Dt. 27/03/2019. The restaurant premise was re-inspected by the officer concerned of this department on 23/02/2022 in the presence of Mr. Shivam Tyagi (Manager) of the restaurant and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** (Restaurant at Ground and First Floor only) as above with effect from 08/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08 / 03 / 2022 at New Delhi by



(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Dy. Health Officer, Public Health Department, South Zone, Green Park, Delhi-16 (Ref. MHA Portal ID 2022020901866 dated 09/02/2022).
2. M/s Bikanervala Foods Pvt Ltd. located at Property No 14 & 15, Community Centre, Malviya Nagar Extension, Saket, New Delhi 110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	M/s Bikanervala Foods Pvt Ltd. located at Property No 14 & 15, Community Centre, Malviya Nagar Extension, Saket, New Delhi 110017		
2	Type of Occupancy	Group-D-4 Assembly (Restaurant at GF & 1 st Floor)		
3	Building Comprised of	Basement, Ground + 03 upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2019/SZ/648 Dt. 27/03/2019		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04/04/2005		
7	Date of Inspection	23/02/2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shivam Tyagi (Manager)		
10	Year of construction	1996		
11	Applicant letter No.	MHA Portal ID 2022020901866 dated 09/02/2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	4.50 m	Provided	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	Upper floors.	02 No's upto 1 st floor	Provided	MR (old case)
	Basement floor.	01 No	Provided	MR (old case)
	b. Width of Staircase			
	Upper floors	Reqd. 02 Nos	1.20 m & 1.09m	MR (old case)
	c. Basement floor	1.2 m (old case)	1.2 m provided	MR (old case)
	d. Protection of exits			
	Fire check door	N/A	N/A	N/A
	e. Pressurization	N/A	N/A	N/A
	f. No. of continuous staircase to terrace	Required 01 No	Provided	MR
	g. Width of corridor	N/A	N/A	N/A
	h. Door size	1 mtr	1 mtr & 1.14 mtr	MR (old case)
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	30 ACPH	Exhaust fan provided	MR
	Upper floors	12 ACPH	Exhaust fan provided	MR
5	Fire Extinguishers.			
	Total numbers	10 Nos	08 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR

N/200

	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	N/A	N/A	N/A
	Restaurant area	Required	Provided	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	100 mm	Provided	MR
	Number of Hydrant per floor	One	Provided	MR
	Hose box.	One	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	180 LPM at GF	Provided	MR
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 LPM at GF	Provided	MR (old case)
	Head of pump.	35m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	Required	Provided 2 way	MR
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			

	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A
	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2019/SZ/648 Dt. 27/03/2019, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]

Signature of the Inspecting Officer
Name: - Sh. Rajesh Kumar
Designation: - ADO/BCP

~~DO (SD)~~

[Handwritten signature]

~~DO (SD)~~

F. T.

[Handwritten signature]

ADO/BCP,

As approved, F.T. letter is forup for your

signature pl

1/14
3/3/2022

~~DO (SD)~~

[Handwritten signature]

M. S. cell