

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2022/SZ/ 273

Dated: 14/03/2022

FIRE SAFETY CERTIFICATE

Certified that **Bal Vaishali Public School** located at **I-28, Harkesh Nagar, New Delhi-110020** comprised of ground plus three upper floors was issued FSC by this department vide letter No. F6/DFS/MS/School/2019/SZ/109 Dated 15-01-2019. The premises was re-inspected by officer concerned of this department on 05/03/2022 in presence of Mr. Laxmi Kant (Manager) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, as above with effect from 14/03/2022 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/03/2022 at New Delhi by



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The Principal, Bal Vaishali Public School at I-28, Harkesh Nagar, New Delhi-110020
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	Bal Vaishali Public School located at I-28 Harkesh Nagar, New Delhi-110020		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2019/SZ/109 Dated 15-01-2019		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	05-03-2022		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Laxmi Kant (Manager)		
10	Year of construction	Before 1988		
11	Applicant letter No.	Outdoor Diary No. 6645 dated 17-02-2022		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mtr	6m road at a distance of 02 length of hose pipe	MR as approved by FPW Committee on 13.08.2013
		Required	4 mtr	MR
		-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.30m & 1m	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH	-NA-	-NA-
		12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required	14 Nos	MR
		ABC/CO2	ABC & CO2	MR
		ISI mark	Provided	MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One	Provided	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection & alarming system.			

	<ul style="list-style-type: none"> • Flow switch panel. • PA system panel. • Battery backup • Building floor plan 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The fire protection system provided in the building was test checked at random and found functional at the time of inspection</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/School/2019/SZ/109 Dated 15-01-2019, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
<p>Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>				

1/14
09/03/2022

Bal Vaishali Public School located at I-28, Harkesh Nagar, New Delhi-110020

DO (SD)

ADO (BCP)

As approved, F.T. letter is put up for your signature pl.

1/14
09/03/2022

M.S. cell