

C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2022/NDZ/ 65

Dated: 11/03/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Ethnic Foods Pvt. Ltd. located at running on ground floor of DMRC Dilshad Garden metro station, Delhi-110095 owned/occupied by M/s Haldiram Ethnic Food Pvt. Ltd was issued FSC vide letter No.F6/DFS/MS/EH/2017/1371 dated 15/09/17. The restaurant building was re-inspected by the officer concerned of this department in presence of Mrs. Madhuri(Shift Manager) and found that the restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the restaurant building is fit for ground floor occupancy Group D "Assembly Building" with effect from 11/03/2022 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.


Issued on..... 11/03/2022 at New Delhi by


11/3/22

(Dr. S.K Tomar)
Dy.Chief Fire Officer

To,

M/s Haldiram Ethnic Food Pvt. Ltd.
Gf, Metro Station Dilshad Garden,
Shahdara, Delhi-110095.


o/c

MHA ID-2021102825349, Dated- 29/10/2021

Copy:-

The Dy. Health Officer,
Shahdara (South Zone, EDMC,
Health Department, Shahdara South Zone,
Karkardooma, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/21

1. Name & address of the building : Haldiram Ethnic Foods PVT. Ltd.
GF, Metro Station, Dilshad Garden,
Shahdara Delhi – 110095.
2. Building is comprised of : Building is ground plus two upper floors
(Restaurant is running on ground floor only)
(Mezzanine Floor Use for storage)
3. Type of Occupancy : Restaurant (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/EH/2017/1371 DT-15/09/2017
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 04/02/2022
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mrs. Madhuri (Shift Manager)
10. Year of Construction : 2008
11. Applicant's letter No : MHA ID-2021102825349, Dated- 29/10/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12mtr.	28mtr.	MR
	• Gate width	4.50mtrs	06mtrs	MR
	• Width of internal road	06mtrs	06mtrs	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Mezzanine floor	01 no.	01 no.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Mezzanine floor	1.5 mtr.	1.5 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	2.10 mtr, 1.65 Mtr & 1.20 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	45 mtr	45 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	Smoke/Heat	MR
	• Location of main panel	N/A	Provided	MR
	• Location of repeater panel	N/A	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	Near Gate	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Metro Station		
	• Discharge of main pump	1800 lpm	1800 lpm	MR
	• Head of main pump	70 mtrs	70 mtrs	MR
	• Number of main pumps	02 nos	02 nos	MR
	• Jockey pump out put	180 lpm	180 lpm	MR
	• Jockey pump head	40 mtr	40 mtr	MR
	• Standby pump out put	2850 lpm	2850 lpm	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	• Sprinkler Main pump	2850 lpm	2850 lpm	MR
	• Head of the pump	70 mtr	70 mtr	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	Common with metro station			
	• Underground tank capacity	50,000 ltrs	2,00, 000 ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

2/23

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The shortcomings communicate earlier vide letter No. F6/DFS/MS/EH/2021/NDZ/342 dated 12/08/2021 have been rectified now.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, It is recommended to renew Fire Safety Certificate under rule 35 of Delhi Fire Service, Rules 2010.

Mehmood
10/2/2022

Signature of the Inspecting Officer
Name :- Mehmood
Designation :- ADO(T.P)

Dy.CFO(NDZ) *Pi. speak*
K. Jomir
11/2/22
spoken

ADOC(T.P)
Sir, the undertaking given by them placed at C/45, may like to see.
Re. Subsoni used please
Mehmood
5/3/22



Dy CFO (NDZ)
Sir, *As P.T. letter put up for signature please*
Mehmood
11/3/22
ADOC(T.P)
Dy CFO (NDZ)