

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

C-33


No. F6/DFS/MS/School/WZ/2022/ 266

Dated: 11/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Sarvodaya Kanya Vidyalaya (ID-1516027)** located at **Ramesh Nagar, New Delhi-110027**, comprised of Block-2 Ground + One Upper Floor only & MP Hall, Was issued FSC vide letter No. F6DFS/MS/School/2019/402 dated 13/02/2019. The Premises was re-inspected by the officer concerned by this department on 26/02/2022 in the presence of Smt. Ritu Sawhney (H.O.S.) and observed that the fire prevention and fire safety arrangements provided in the Building/premises found in good working condition. The premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE 3298-3398 dated 01/03/2011 and that the building / premises is fit for the occupancy class "**Educational**" **Group B (with MP Hall)** with effect from 11/03/2022 for a period of three years subject to compliance of the condition mentioned below.

Issued on 11/03/2022 at New Delhi.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer,  
Delhi Fire Service

**Copy to:**

1. The Principal, Govt. Sarvodaya Kanya Vidyalaya (ID-1516027) Ramesh Nagar, New Delhi-110027,
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya Located at Ramesh Nagar, New Delhi-110027 (School ID-1516027)
2. Type of Occupancy : Educational (Ground + One Upper Floor & One MP HALL)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2019/402 dated 13/02/2019
5. Fire Safety directives letter No : DOE 3298-3398 dated 01/03/2011
6. Date of inspection : 26/02/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Smt. Ritu Sawhney (H.O.S.)
9. Year of Construction : 2021
10. Applicant's letter No. : Email dated 14/02/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE 3298-3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	Provided	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5m	BL-1=150cm,125cm,117cm, BL-2=150cm	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization			
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5m	216cm & 152cm provided	MR
	g. Door Size	1 mtr	103 cm Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	15 nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	Provided	NA
	• Length of hose reel hose	NA	Provided	NA
	• Nozzle diameter	NA	Provided	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NR	Provided	NR
	• Number of hydrants per floor	NR	Provided	NR
	• Hose Box	NR	Provided	NR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	450 lpm Provided	NA
	➤ Head of the pump	NA	Provided	NA
	➤ Power Supply	NA	Provided	NA
	➤ Auto Starting of pump	NA	Provided	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	10,000 ltr Provided	NA
15	<b>Exit Signage.</b>	Required	Provided	MR

82

Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/SCHOOL/2019/402 dated 13/02/2019 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

48/ADO/MN  
28/2/22

~~(Do west)~~

~~Sarajeet Singh~~  
03/03/22  
Sarajeet Singh  
ADO (MN)

D.O. (WEST) 395-  
DATED 03/03/2022

~~DO~~ 02/03/2022  
~~DO (WZ)~~  
4/3/2022

~~ADO/MN~~  
ADO/MN

Div, F.T is put up for your personal & signature please.

~~ADO (WZ)~~  
9/3/2022

~~Sarajeet Singh~~  
08/03/2022

not call