

E-19

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/EH/68

Dated: 14/03/2022

FIRE SAFETY CERTIFICATE

Certified that the M/s Barcode (A unit of M/s the vintage boulevard) Located at 3rd floor Plot No. 228, Sector – 9, Dwarka, New Delhi – 110075, in a building comprised of Basement + Ground + 03 Upper Floors owned/ occupied By M/s Barcode (A unit of M/s the vintage boulevard) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 25/02/2022 in the presence of Sh. Sanjay Pal and found that the said building that the premises is fit for occupancy class “ Assembly” Group D (At Entire 3rd Floor only) with effect from 14/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/03/2022 at New Delhi by.


(Anil Garg)
Director
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, N Delhi.
2. The Dy. Health Officer, South Delhi Municipal Corporation, Najafgarh Zone, Dhansa Stand Najafgarh New Delhi.
3. The Manager M/s Barcode (A unit of the vintage boulevard) Located at Plot no. 228, 3rd floor Sector – 9, Dwarka, New Delhi – 110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/7

Re inspection to see the compliance of shortcomings communicated vide letter dated. 06/10/2021 are complied

INSPECTION REPORT

1. Name & address of the building: M/s Barcode A unit of the vintage boulevard Located at 3rd Floor, Plot no. 228, Sector – 9, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Assembly "D" Restaurant
3. Type of Case : New (Building comprised of G + 3 upper floor
(Restaurant running at Third Floor))
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : BBL/NBC Part IV
6. Date of inspection : 25-02-2022
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Sanjay Pal
9. Year of Construction : 2004
10. Applicant's letter No. : Email Dated 21-02-2022

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02 (Two 3 rd floor to terrace)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x1.5m.	2x1.5m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x1.5 mtr	Provided	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hpur	NA	NA
	• Upper floors	12 ac per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	4 nos. CO2 or ABC	04 Nos.	MR
	• Types	ABC	ABC	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 Nos.	Provided	MR
	• Hose Box	01 Nos.	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

W *Z*


13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2280 lpm	Provided	MR
		50 mtr	Provided	MR
		01	Provided	MR
		180 lpm	Provided	MR
		50 mtr	Provided	MR
		2280 lpm	Provided	MR
		50 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450 lpm	Provided	MR
		30 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	100,000 ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	DG Set	MR
18	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA


N/10

20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


 2/8/2022
 Sign. of the Inspecting Officer
 Name Sh. Vedpal
 Designation DO/SK


 28/2/22
 Sign. of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADO/DWA


Dy CEO (SZ)


 3/3


CEO. (D. off)

Director
 7/03/2022

DO/SK
 9/3

ADO (Dwarka)


Sir Pt. letter is put up for
 sign ple


 9/3/22
 14/03/22
 14/03/22