

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2022/School/287

Dated: 16/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the building of Delhi English Academy School Located at Village Dhool Siras, Sector - 26, Dwarka, New Delhi - 110077 having two blocks, comprised of 01 Block G + 1UF & II-Block Ground floor only, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2017/SZ/390 Dated 16/03/2017. The premises was re inspected by the officer concerned of this department on 04/03/2022 in the presence of Sh. R.K Sharma (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 16/03/2022 for a period of three years.

Issued on 16/03/2022 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. Directorate of Education Old Secretariat Delhi - 110054.
2. Sh. R.K Sharma ( Principal) Delhi English Academy School Located at Village Dhool Siras, Sector - 26, Dwarka, New Delhi - 110077

**Following fire safety directives must be adhered to:-**

- 1 The 2<sup>nd</sup> Floor found under construction during the inspection. It will not be occupied without getting clearance from this department.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

ADP  
16/03/22

INSPECTION REPORT

1. Name & address of the building: Delhi English Academy School Located at Village Dhool Siras, Sector - 26, Dwarka, New Delhi - 110077
2. Type of Occupancy : Educational (02 Blocks 01- BL= G + 1UF & II -BL= Ground floor only )
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/390 Dated 16/03/2017
5. Fire Safety directives Letter No. : Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 04/03/2022
7. Name of the Inspecting Officer : Udai vir singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. R.K Sharma( Principal)
9. Year of Construction : Old Block 1996 & New Block 2016
10. Applicant's letter No. : DEA/2022/Fire/A3 Dated - 14/02/2022

S No.	Minimum standards on fire prevention and fire safety U/R 33	As per N/7	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	6 mtr	MR
	• Gate width	4.5	Provided (Old case)	MR(Old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.5 mtr each	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	02	MR
	e. Width Of Corridor	1.5 mtr	2.25 mtr	MR
	f. Door Size	01 mtr	1 mtr	MR, old Case
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	01 .ABC or CO <sub>2</sub> For every 300 sq. mtr.ISI marked		Provided MR
	• Types			Provided MR
	• IS marking			ISI marked MR

*(Handwritten Signature)*

24/12

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

M/13

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2017/SZ/390 Dated 16/03/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

**Note :- The 2<sup>nd</sup> Floor found under construction during the inspection. It will not be occupied without getting clearance from this department.**

Signature of the Inspecting Officer  
 Name *Udai Vir Singh*  
 Designation *ADDO/DWJ*

*10/13/22*

*DD/S2*

*WS 8/2/2022 F, Y*

*Dycho(S2)*

*M.S. all A DO/DWK*

*Sir AP letter is put up for sign ple*

*10/13/22*

*Dycho/S2*

*[Signature]*

*M.S. all*