

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F6/DFS/MS/School/WZ/2022/284

Dated: 14/03/2022

FIRE SAFETY CERTIFICATE

Certified that the **Nigam prathiba Vidyalaya (ID-2161416)** located at **Nimri Village, Shastri Nagar, New Delhi-110052**, comprised of Ground Floor + 02 Upper Floors owned/Occupied by **Nigam prathiba Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Act 2007 and Delhi Fire Service Rules 2010, and verified by the officer concerned of this department on 28/02/2022 in the presence of Smt. Kusum (H.O.S.) and found that the building / premises is fit for the occupancy class "**Educational**" **Group B** with effect from 14/03/2022 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 14/03/2022 at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal, Nigam Prathiba Vidyalaya, Nimri Village, Shastri Nagar, New Delhi-110052 (ID-2161416).
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Nigam Prathiba Vidyalaya, located at Satyawati Nagar, New Delhi-110052 (School ID - 1354140)
2. Type of Occupancy : Educational (Ground Floor + 02 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2018/2550 dated 26/11/2018
5. Fire Safety directives letter No : 3298-3398 dated 01/03/2011
6. Date of inspection : 23/02/2022
7. Name of the Inspecting Officers : Sarabjeet Singh, ADO (MN)
8. Name and designation of officers from the building side : Smt. Sheela Jain (Principal)
9. Year of Construction : 1989 (As per previous insp. report dtd.- 29/10/2018)
10. Applicant's letter No. : Letter No. Nil dated 07/02/2022

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement/	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	9 mtr Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m	2 X 143 cms, Provided	MR(being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.5 m	Provided	MR
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	10 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Non functional	NMR
	• Length of hose reel hose	30m	Non functional	NMR
	• Nozzle diameter	5mm	Non functional	NMR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Non functional	NMR
	➤ Head of the pump	40 m	Non functional	NMR
	➤ Power Supply	Required	Non functional	NMR
	➤ Auto Starting of pump	Required	Non functional	NMR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Found Empty	NMR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~DO (west)~~

~~Signature~~
02/03/2022

S3/ADO/MN
02/03/2022

Signature of the Inspecting
Name: - Sarabjeet Singh
Designation: - ADO (MN)

What is width of Road?

~~Signature~~
02/02/2022

ADO (MN)

Sir, width of the road is 9 mtr. (unbound)
in inspection performa.

Submitted pls.

~~Signature~~
8/3/22
688

~~Signature~~
04/03/2022

D.O. (WEST) 358
DATED... 4/3/2022

~~Signature~~
04/03/2022

~~DO (W2)~~

~~Signature~~
4/3/2022

~~Signature~~

~~Signature~~
02/03/2022

~~Signature~~
02/03/2022